

School Name	Sample ID	Location	Copper (Cu) mg/L	Copper Result	Lead (Pb) mg/L	Lead Result	Remediation: all schools will continue to receive clean drinking water.
Barrington Municipal High School	BH10-BF-P-001	Bathroom Faucet	3.7750	Exceeds Limit	0.0560	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH11-SF-P-001	Staff Faucet	4.7130	Exceeds Limit	0.0830	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH12-BF-P-001	Bathroom Faucet	2.8130	Exceeds Limit	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH13-BF-P-001	Bathroom Faucet	1.8030	Passed	0.0180	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH14-SF-P-001	Staff Faucet	1.4590	Passed	0.0130	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH15-WF-P-001	Water Fountain	0.0200	Passed	0.0010	Passed	
Barrington Municipal High School	BH16-BF-P-001	Bathroom Faucet	2.4700	Exceeds Limit	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH17-BF-P-001	Bathroom Faucet	1.5040	Passed	0.0420	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH18-BF-P-001	Bathroom Faucet	1.3070	Passed	0.0590	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH19-WF-P-001	Water Fountain	4.8810	Exceeds Limit	0.0020	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH1-BF-P-001	Bathroom Faucet	2.3930	Exceeds Limit	0.0240	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH20-WF-P-001	Water Fountain	1.6870	Passed	0.0670	Exceeds Limit	Fountain to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH21-BF-P-001	Bathroom Faucet	2.9610	Exceeds Limit	0.0500	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH22-CF-P-001	Classroom Faucet	4.0390	Exceeds Limit	0.0610	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH23-BF-P-001	Bathroom Faucet	1.9910	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH24-WF-P-001	Water Fountain	10.7500	Exceeds Limit	0.0040	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH25-BF-P-001	Bathroom Faucet	1.0500	Passed	0.0500	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH26-BF-P-001	Bathroom Faucet	2.1780	Exceeds Limit	0.0290	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH27-BF-P-001	Bathroom Faucet	1.5870	Passed	0.0260	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH28-BF-P-001	Bathroom Faucet	1.4720	Passed	0.0310	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH29-BF-P-001	Bathroom Faucet	3.0830	Exceeds Limit	0.0290	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH2-BF-P-001	Bathroom Faucet	1.1080	Passed	0.0380	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH30.1-CF-P-001	Classroom Faucet	3.1540	Exceeds Limit	0.0050	Passed	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH30-BF-P-001	Bathroom Faucet	2.4430	Exceeds Limit	0.0360	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH31.1-CS-P-001	Custodial Sink	2.1920	Exceeds Limit	0.0230	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH31-CS-P-001	Custodial Sink	4.3900	Exceeds Limit	0.0270	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH32-BF-P-001	Bathroom Faucet	1.5130	Passed	0.0180	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH33-KF-P-001	Kitchen Faucet	1.9340	Passed	0.0180	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH34.1-KF-P-001	Kitchen Faucet	1.4220	Passed	0.0080	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH34-KF-P-001	Kitchen Faucet	2.7800	Exceeds Limit	0.0140	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH35-KF-P-001	Kitchen Faucet	4.7660	Exceeds Limit	0.0980	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH36-CS-P-001	Custodial Sink	1.5270	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH37-CF-P-002	Classroom Faucet	1.9970	Passed	0.0150	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH38-CF-P-002	Classroom Faucet	1.6070	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH39-BF-P-002	Bathroom Faucet	1.7700	Passed	0.0180	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH3-BF-P-001	Bathroom Faucet	2.6550	Exceeds Limit	0.0720	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH40-WF-P-002	Water Fountain	2.2310	Exceeds Limit	0.0010	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Barrington Municipal High School	BH41-BF-P-002	Bathroom Faucet	1.9050	Passed	0.0310	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH42-BF-P-002	Bathroom Faucet	1.1030	Passed	0.0200	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH43-BF-P-002	Bathroom Faucet	1.7810	Passed	0.0400	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH44-BF-P-002	Bathroom Faucet	2.1890	Exceeds Limit	0.0300	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH45-BF-P-002	Bathroom Faucet	2.3460	Exceeds Limit	0.0430	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH46-BF-P-002	Bathroom Faucet	2.3780	Exceeds Limit	0.0390	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH47-CS-P-002	Custodial Sink	2.6850	Exceeds Limit	0.0240	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH48-CF-P-002	Classroom Faucet	3.7790	Exceeds Limit	0.0600	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH49-CF-P-002	Classroom Faucet	2.6880	Exceeds Limit	0.0280	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH4-BF-P-001	Bathroom Faucet	2.2710	Exceeds Limit	0.0400	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH50-CF-P-002	Classroom Faucet	2.5880	Exceeds Limit	0.0290	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH51-CF-P-002	Classroom Faucet	4.3370	Exceeds Limit	0.0820	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH52-CF-P-002	Classroom Faucet	2.0040	Exceeds Limit	0.0720	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH53-CF-P-002	Classroom Faucet	0.5860	Passed	0.0250	Exceeds Limit	Signage to be added to instruct handwashing only

Barrington Municipal High School	BH54-CF-P-002	Classroom Faucet	2.1780	Exceeds Limit	0.0780	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH55-CF-P-002	Classroom Faucet	1.3810	Passed	0.0350	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH56-BF-P-002	Bathroom Faucet	3.7190	Exceeds Limit	0.0380	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH57-CF-P-002	Classroom Faucet	1.8670	Passed	0.0450	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH58-CF-P-002	Classroom Faucet	3.1340	Exceeds Limit	0.0560	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH59-CF-P-002	Classroom Faucet	3.0910	Exceeds Limit	0.0780	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH5-CS-P-001	Custodial Sink	3.5420	Exceeds Limit	0.0390	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH60-CF-P-002	Classroom Faucet	2.1470	Exceeds Limit	0.0750	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH61-CF-P-002	Classroom Faucet	3.3140	Exceeds Limit	0.0500	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH62-CF-P-002	Classroom Faucet	2.1070	Exceeds Limit	0.0690	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH63-CF-P-002	Classroom Faucet	1.0400	Passed	0.0410	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH64-CF-P-002	Classroom Faucet	1.4450	Passed	0.1770	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH65.1-CF-P-002	Classroom Faucet	2.2920	Exceeds Limit	0.0750	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH65-CF-P-002	Classroom Faucet	2.2470	Exceeds Limit	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH66-CF-P-002	Classroom Faucet	1.6670	Passed	0.1410	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH67-CF-P-002	Classroom Faucet	1.7760	Passed	0.0950	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH68-CF-P-002	Classroom Faucet	1.8930	Passed	0.0270	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH69-CF-P-002	Classroom Faucet	2.5400	Exceeds Limit	0.0780	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH6-BF-P-001	Bathroom Faucet	2.1050	Exceeds Limit	0.0540	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH70-CF-P-002	Classroom Faucet	1.2060	Passed	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH71-BF-P-002	Bathroom Faucet	1.9540	Passed	0.0230	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH72-BF-P-002	Bathroom Faucet	2.1090	Exceeds Limit	0.0250	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH73-BF-P-002	Bathroom Faucet	2.8540	Exceeds Limit	0.0260	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH74-CS-P-002	Custodial Sink	2.4280	Exceeds Limit	0.0720	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH75-BF-P-002	Bathroom Faucet	1.1100	Passed	0.0530	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH76-BF-P-002	Bathroom Faucet	2.4340	Exceeds Limit	0.0670	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH77-BF-P-002	Bathroom Faucet	1.4320	Passed	0.0450	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH78-WF-P-002	Water Fountain	0.0140	Passed	0.0010	Passed	
Barrington Municipal High School	BH79-CF-P-002	Classroom Faucet	2.1430	Exceeds Limit	0.0580	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH7-BF-P-001	Bathroom Faucet	2.4420	Exceeds Limit	0.0310	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH8.1-CF-P-001	Classroom Faucet	1.0460	Passed	0.0210	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH80-CF-P-002	Classroom Faucet	2.1930	Exceeds Limit	0.0510	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH81-CF-P-002	Classroom Faucet	1.8190	Passed	0.0380	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH82-CF-P-002	Classroom Faucet	2.2040	Exceeds Limit	0.0230	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH84-CF-P-002	Classroom Faucet	2.1200	Exceeds Limit	0.0220	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH85.1-BF-P-002	Bathroom Faucet	1.7230	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH85.2-BF-P-002	Bathroom Faucet	5.0190	Exceeds Limit	0.0200	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH85-BF-P-002	Bathroom Faucet	2.2490	Exceeds Limit	0.0260	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH8-BF-P-001	Bathroom Faucet	2.2210	Exceeds Limit	0.0380	Exceeds Limit	Signage to be added to instruct handwashing only
Barrington Municipal High School	BH9-CF-P-001	Classroom Faucet	4.0690	Exceeds Limit	0.0560	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC10-BF-P-001	Bathroom Faucet	0.1580	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC11flush-KF-F-001	Kitchen Faucet	0.2610	Passed	0.0110	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Carleton Consolidated School	CC11-KF-P-001	Kitchen Faucet	0.1030	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC11-KF-S-001	Kitchen Faucet	0.1140	Passed	0.0070	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Carleton Consolidated School	CC13flush-KF-F-001	Kitchen Faucet	0.2610	Passed	0.0100	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Carleton Consolidated School	CC13-KF-P-001	Bathroom Faucet	0.2000	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC13-KF-S-001	Kitchen Faucet	0.2290	Passed	0.0300	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Carleton Consolidated School	CC14-BF-P-001	Bathroom Faucet	0.0820	Passed	0.0030	Passed	
Carleton Consolidated School	CC15-BF-P-001	Bathroom Faucet	0.0910	Passed	0.0030	Passed	
Carleton Consolidated School	CC16-BF-P-001	Bathroom Faucet	0.0530	Passed	0.0020	Passed	
Carleton Consolidated School	CC17-BF-P-001	Bathroom Faucet	0.0950	Passed	0.0030	Passed	
Carleton Consolidated School	CC18-BF-P-002	Bathroom Faucet	0.1840	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only

Carleton Consolidated School	CC19-BF-P-002	Bathroom Faucet	0.1690	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC1-BF-P-001	Bathroom Faucet	0.1130	Passed	0.0030	Passed	
Carleton Consolidated School	CC20-BF-P-002	Bathroom Faucet	0.2220	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC21-BF-P-002	Bathroom Faucet	0.2080	Passed	0.0150	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC22-WF-P-002	Water Fountain	0.0470	Passed	0.0010	Passed	
Carleton Consolidated School	CC23-CS-P-002	Custodial Sink	0.1090	Passed	0.0030	Passed	
Carleton Consolidated School	CC24-BF-P-002	Bathroom Faucet	0.2000	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC25-BF-P-002	Bathroom Faucet	0.1610	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC26-BF-P-002	Bathroom Faucet	0.1570	Passed	0.0080	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Carleton Consolidated School	CC27-CF-P-002	Classroom Faucet	0.1100	Passed	0.0050	Passed	
Carleton Consolidated School	CC28-BF-P-002	Bathroom Faucet	0.1770	Passed	0.0050	Passed	
Carleton Consolidated School	CC29flush-SF-F-002	Staff Faucet	0.0380	Passed	0.0010	Passed	
Carleton Consolidated School	CC29-SF-P-002	Staff Faucet	0.1240	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC29-SF-S-002	Staff Faucet	0.0390	Passed	0.0010	Passed	
Carleton Consolidated School	CC2-BF-P-001	Bathroom Faucet	0.1370	Passed	0.0030	Passed	
Carleton Consolidated School	CC3.1-WF-P-001	Water Fountain	0.0920	Passed	0.0020	Passed	
Carleton Consolidated School	CC30-CF-P-002	Classroom Faucet	0.2210	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC3-BF-P-001	Bathroom Faucet	0.3150	Passed	0.0160	Exceeds Limit	Signage to be added to instruct handwashing only
Carleton Consolidated School	CC4-BF-P-001	Bathroom Faucet	0.2240	Passed	0.0030	Passed	
Carleton Consolidated School	CC5-BF-P-001	Bathroom Faucet	0.1440	Passed	0.0040	Passed	
Carleton Consolidated School	CC6-BF-P-001	Bathroom Faucet	0.1630	Passed	0.0030	Passed	
Carleton Consolidated School	CC7-BF-P-001	Bathroom Faucet	0.1780	Passed	0.0030	Passed	
Carleton Consolidated School	CC8-BF-P-001	Bathroom Faucet	0.1410	Passed	0.0020	Passed	
Carleton Consolidated School	CC9-WF-P-001	Water Fountain	0.0880	Passed	0.0010	Passed	
Clark's Harbour Elementary School	CH10-CS-P-001	Custodial Sink	0.8270	Passed	0.0050	Passed	
Clark's Harbour Elementary School	CH11-BF-P-001	Bathroom Faucet	0.7880	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH12-BF-P-001	Bathroom Faucet	0.6660	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH13-BF-P-001	Bathroom Faucet	0.7790	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH14-BF-P-001	Bathroom Faucet	0.6530	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH15-BF-P-001	Bathroom Faucet	0.7170	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH16-WF-P-001	Water Fountain	0.1380	Passed	0.0010	Passed	
Clark's Harbour Elementary School	CH17-BF-P-001	Bathroom Faucet	0.7760	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH18-SF-P-001	Staff Faucet	0.7260	Passed	0.0070	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Clark's Harbour Elementary School	CH19-CS-P-001	Custodial Sink	1.4280	Passed	0.0230	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH21-WF-P-001	Water Fountain	0.4860	Passed	0.0030	Passed	
Clark's Harbour Elementary School	CH22-BF-P-001	Bathroom Faucet	0.9510	Passed	0.0040	Passed	
Clark's Harbour Elementary School	CH23-BF-P-001	Bathroom Faucet	0.9790	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH24-BF-P-001	Bathroom Faucet	0.9490	Passed	0.0050	Passed	
Clark's Harbour Elementary School	CH2-KF-P-001	Kitchen Faucet	0.6720	Passed	0.0060	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Clark's Harbour Elementary School	CH3-KF-P-001	Kitchen Faucet	0.9020	Passed	0.0180	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Clark's Harbour Elementary School	CH4-BF-P-001	Bathroom Faucet	0.6590	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH5-BF-P-001	Bathroom Faucet	1.0750	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH6-BF-P-001	Bathroom Faucet	1.2150	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH7-BF-P-001	Bathroom Faucet	1.0330	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH8-BF-P-001	Bathroom Faucet	1.3500	Passed	0.0260	Exceeds Limit	Signage to be added to instruct handwashing only
Clark's Harbour Elementary School	CH9-BF-P-001	Bathroom Faucet	1.0180	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE10-WF-P-001	Water Fountain	0.0210	Passed	-	Passed	
Digby Elementary School	DE11-CS-P-001	Custodial Sink	0.1030	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE12-BF-P-001	Bathroom Faucet	0.0900	Passed	0.0030	Passed	
Digby Elementary School	DE13-BF-P-001	Bathroom Faucet	0.0640	Passed	0.0050	Passed	
Digby Elementary School	DE14-BF-P-001	Bathroom Faucet	0.0760	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE15-BF-P-001	Bathroom Faucet	0.0610	Passed	0.0050	Passed	

Digby Elementary School	DE16-BF-P-001	Bathroom Faucet	0.0580	Passed	0.0010	Passed	
Digby Elementary School	DE17-BF-P-001	Bathroom Faucet	0.0530	Passed	0.0010	Passed	
Digby Elementary School	DE18-BF-P-001	Bathroom Faucet	0.0550	Passed	0.0020	Passed	
Digby Elementary School	DE19-BF-P-001	Bathroom Faucet	0.0460	Passed	0.0020	Passed	
Digby Elementary School	DE1-BF-P-001	Bathroom Faucet	0.1010	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE20-BF-P-001	Bathroom Faucet	0.0520	Passed	0.0010	Passed	
Digby Elementary School	DE21-CF-P-001	Classroom Faucet	0.2160	Passed	0.1010	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE22-CF-P-001	Classroom Faucet	0.0640	Passed	0.0020	Passed	
Digby Elementary School	DE23-BF-P-001	Bathroom Faucet	0.0300	Passed	0.0020	Passed	
Digby Elementary School	DE24-BF-P-001	Bathroom Faucet	0.0420	Passed	0.0010	Passed	
Digby Elementary School	DE25-CF-P-001	Classroom Faucet	0.0370	Passed	0.0010	Passed	
Digby Elementary School	DE26-BF-P-001	Bathroom Faucet	0.0290	Passed	0.0010	Passed	
Digby Elementary School	DE27.1-CF-P-001	Classroom Faucet	0.0260	Passed	0.0030	Passed	
Digby Elementary School	DE27.2-CF-P-001	Classroom Faucet	0.0460	Passed	0.0050	Passed	
Digby Elementary School	DE27-CF-P-001	Classroom Faucet	0.0460	Passed	0.0010	Passed	
Digby Elementary School	DE28-WF-P-002	Water Fountain	0.0780	Passed	-	Passed	
Digby Elementary School	DE29-CS-P-002	Custodial Sink	0.0690	Passed	0.0010	Passed	
Digby Elementary School	DE2-WF-P-001	Water Fountain	0.0160	Passed	-	Passed	
Digby Elementary School	DE30-BF-P-002	Bathroom Faucet	0.1390	Passed	0.0040	Passed	
Digby Elementary School	DE31-BF-P-002	Bathroom Faucet	0.0820	Passed	0.0020	Passed	
Digby Elementary School	DE32-BF-P-002	Bathroom Faucet	0.0610	Passed	0.0010	Passed	
Digby Elementary School	DE33-BF-P-002	Bathroom Faucet	0.1400	Passed	0.0040	Passed	
Digby Elementary School	DE34-BF-P-002	Bathroom Faucet	0.0470	Passed	0.0020	Passed	
Digby Elementary School	DE35-BF-P-002	Bathroom Faucet	0.0350	Passed	0.0030	Passed	
Digby Elementary School	DE36-BF-P-002	Bathroom Faucet	0.0980	Passed	0.0010	Passed	
Digby Elementary School	DE37-BF-P-002	Bathroom Faucet	0.0440	Passed	0.0010	Passed	
Digby Elementary School	DE38-BF-P-002	Bathroom Faucet	0.0270	Passed	0.0010	Passed	
Digby Elementary School	DE39-BF-P-002	Bathroom Faucet	0.0420	Passed	0.0020	Passed	
Digby Elementary School	DE3-BF-P-001	Bathroom Faucet	0.0920	Passed	0.0010	Passed	
Digby Elementary School	DE4.1-CF-P-001	Classroom Faucet	0.1050	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE4.2-CF-P-001	Classroom Faucet	0.1250	Passed	0.0040	Passed	
Digby Elementary School	DE4.3-BF-P-001	Bathroom Faucet	0.1120	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE4.4-CF-P-001	Classroom Faucet	0.0870	Passed	0.0050	Passed	
Digby Elementary School	DE40-CF-P-002	Classroom Faucet	0.1030	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Elementary School	DE4-BF-P-001	Bathroom Faucet	0.0090	Passed	0.0010	Passed	
Digby Elementary School	DE5-SF-P-001	Staff Faucet	0.0820	Passed	0.0080	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Digby Elementary School	DE6-BF-P-001	Bathroom Faucet	0.1030	Passed	0.0030	Passed	
Digby Elementary School	DE7-BF-P-001	Bathroom Faucet	0.0250	Passed	0.0010	Passed	
Digby Elementary School	DE8-KF-P-001	Kitchen Faucet	0.0600	Passed	0.0040	Passed	
Digby Elementary School	DE9-KF-P-001	Kitchen Faucet	0.1160	Passed	0.0300	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Digby Neck Consolidated School	DN 15 RE TEST	Classroom Faucet	0.1300	Passed	0.0340	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN 6 RE TEST	Classroom Faucet	0.0560	Passed	0.0065	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN 7 RE TEST	Classroom Faucet	0.0350	Passed	0.0029	Passed	
Digby Neck Consolidated School	DN1 - KF - P - 001	Kitchen Faucet	0.4900	Passed	0.0042	Passed	
Digby Neck Consolidated School	DN10 - WF - P - 001	Water Fountain	0.0260	Passed	-	Passed	
Digby Neck Consolidated School	DN11 - BF - P - 001	Bathroom Faucet	1.6000	Passed	0.0710	Exceeds Limit	Fountain to be decommissioned, remediated, and retested. Other sources available
Digby Neck Consolidated School	DN12 - BF - P - 001	Bathroom Faucet	1.4000	Passed	0.0650	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN13 - BF - P - 001	Bathroom Faucet	2.3000	Exceeds Limit	0.1400	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN2 - KF - P - 001	Kitchen Faucet	0.5900	Passed	0.0042	Passed	
Digby Neck Consolidated School	DN3 - BF - P - 001	Bathroom Faucet	0.3800	Passed	0.0280	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN4 - BF - P - 001	Bathroom Faucet	0.6400	Passed	0.0073	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN5 - BF - P - 001	Bathroom Faucet	0.3000	Passed	0.0068	Exceeds Limit	Signage to be added to instruct handwashing only

Digby Neck Consolidated School	DN6 - CF - P - 001	Classroom Faucet	0.1800	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN7 - CF - P - 001	Classroom Faucet	0.2300	Passed	0.0088	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	DN8 - CF - P - 001	Classroom Faucet	0.7800	Passed	0.0043	Passed	
Digby Neck Consolidated School	DN9 - CS - P - 001	Custodial Sink	0.7800	Passed	0.0062	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Neck Consolidated School	PM14 - BF - P - 001	Bathroom Faucet	1.1000	Passed	0.0330	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR10-BF-P-001	Bathroom Faucet	0.0620	Passed	-	Passed	
Digby Regional High School	DR11-BF-P-001	Bathroom Faucet	0.0660	Passed	0.0010	Passed	
Digby Regional High School	DR12-BF-P-001	Bathroom Faucet	0.0980	Passed	0.0020	Passed	
Digby Regional High School	DR13-BF-P-001	Bathroom Faucet	0.1010	Passed	0.0020	Passed	
Digby Regional High School	DR14-BF-P-001	Bathroom Faucet	0.0530	Passed	-	Passed	
Digby Regional High School	DR15.1-WF-P-001	Water Fountain	-	Passed	-	Passed	
Digby Regional High School	DR15-CS-P-001	Custodial Sink	0.0820	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR16-BF-P-001	Bathroom Faucet	0.2040	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR17-BF-P-001	Bathroom Faucet	0.1980	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR18-BF-P-001	Bathroom Faucet	0.0900	Passed	0.0050	Passed	
Digby Regional High School	DR19-BF-P-001	Bathroom Faucet	0.1150	Passed	0.0030	Passed	
Digby Regional High School	DR1-CS-P-001	Custodial Sink	0.0570	Passed	0.0010	Passed	
Digby Regional High School	DR20-BF-P-001	Bathroom Faucet	0.0820	Passed	0.0020	Passed	
Digby Regional High School	DR21-BF-P-001	Bathroom Faucet	0.1030	Passed	0.0040	Passed	
Digby Regional High School	DR22-BF-P-001	Bathroom Faucet	0.1330	Passed	0.0050	Passed	
Digby Regional High School	DR23.1-WF-P-001	Water Fountain	0.0020	Passed	0.0020	Passed	
Digby Regional High School	DR23-WF-P-001	Water Fountain	0.0170	Passed	0.0010	Passed	
Digby Regional High School	DR24-BF-P-001	Bathroom Faucet	0.0570	Passed	0.0010	Passed	
Digby Regional High School	DR25-CF-P-001	Classroom Faucet	0.0960	Passed	0.0040	Passed	
Digby Regional High School	DR27-CF-P-001	Classroom Faucet	0.0490	Passed	0.0020	Passed	
Digby Regional High School	DR29-CF-P-001	Classroom Faucet	0.0590	Passed	0.0020	Passed	
Digby Regional High School	DR2-CS-P-001	Custodial Sink	0.0530	Passed	-	Passed	
Digby Regional High School	DR31-CF-P-001	Classroom Faucet	0.2650	Passed	0.0040	Passed	
Digby Regional High School	DR33-CF-P-001	Classroom Faucet	0.1140	Passed	0.0050	Passed	
Digby Regional High School	DR34-CF-P-001	Classroom Faucet	1.0260	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR35-CF-P-001	Classroom Faucet	1.0470	Passed	0.0160	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR36-CF-P-001	Classroom Faucet	0.0910	Passed	0.0050	Passed	
Digby Regional High School	DR37-CF-P-001	Classroom Faucet	0.0800	Passed	0.0030	Passed	
Digby Regional High School	DR38-CF-P-001	Classroom Faucet	0.0990	Passed	0.0050	Passed	
Digby Regional High School	DR39-CF-P-001	Classroom Faucet	0.1040	Passed	0.0030	Passed	
Digby Regional High School	DR3-CS-P-001	Custodial Sink	0.0500	Passed	-	Passed	
Digby Regional High School	DR4.1-KF-P-001	Kitchen Faucet	0.0630	Passed	0.0010	Passed	
Digby Regional High School	DR4.2-KF-P-001	Kitchen Faucet	0.0650	Passed	0.0030	Passed	
Digby Regional High School	DR4.3-KF-P-001	Kitchen Faucet	0.0640	Passed	-	Passed	
Digby Regional High School	DR40-CF-P-001	Classroom Faucet	0.1480	Passed	0.0040	Passed	
Digby Regional High School	DR41-CF-P-001	Classroom Faucet	0.1130	Passed	0.0040	Passed	
Digby Regional High School	DR42-CF-P-001	Classroom Faucet	0.1680	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR43-CF-P-001	Classroom Faucet	0.1340	Passed	0.0040	Passed	
Digby Regional High School	DR44-CF-P-001	Classroom Faucet	0.2600	Passed	0.0050	Passed	
Digby Regional High School	DR45-CF-P-001	Classroom Faucet	0.7910	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR46-CF-P-001	Classroom Faucet	0.1800	Passed	0.0030	Passed	
Digby Regional High School	DR47-CF-P-001	Classroom Faucet	0.0840	Passed	0.0040	Passed	
Digby Regional High School	DR49-BF-P-001	Bathroom Faucet	0.0690	Passed	0.0040	Passed	
Digby Regional High School	DR4-KF-P-001	Kitchen Faucet	0.0150	Passed	-	Passed	
Digby Regional High School	DR50-CS-P-001	Custodial Sink	0.1670	Passed	0.0020	Passed	
Digby Regional High School	DR51-CF-P-001	Classroom Faucet	0.0760	Passed	0.0040	Passed	
Digby Regional High School	DR52-CF-P-001	Classroom Faucet	0.0780	Passed	0.0040	Passed	

Digby Regional High School	DR53-BF-P-001	Bathroom Faucet	0.0830	Passed	0.0020	Passed	
Digby Regional High School	DR54-CS-P-001	Custodial Sink	0.1020	Passed	0.0040	Passed	
Digby Regional High School	DR55-CF-P-001	Classroom Faucet	0.4290	Passed	0.0220	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR56-CF-P-001	Classroom Faucet	0.1250	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR57-CF-P-001	Classroom Faucet	0.1240	Passed	0.0050	Passed	
Digby Regional High School	DR58-CF-P-001	Classroom Faucet	0.2330	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR59-CF-P-001	Classroom Faucet	0.0800	Passed	0.0050	Passed	
Digby Regional High School	DR5-BF-P-001	Bathroom Faucet	0.0620	Passed	-	Passed	
Digby Regional High School	DR60-CF-P-001	Classroom Faucet	0.7070	Passed	0.0210	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR61-CF-P-001	Classroom Faucet	0.0950	Passed	0.0050	Passed	
Digby Regional High School	DR62-CF-P-001	Classroom Faucet	0.0850	Passed	0.0030	Passed	
Digby Regional High School	DR63-CF-P-001	Classroom Faucet	0.0520	Passed	0.0030	Passed	
Digby Regional High School	DR64-CF-P-001	Classroom Faucet	0.0850	Passed	0.0030	Passed	
Digby Regional High School	DR65-CF-P-001	Classroom Faucet	0.1460	Passed	0.0050	Passed	
Digby Regional High School	DR66-CF-P-001	Classroom Faucet	0.1130	Passed	0.0040	Passed	
Digby Regional High School	DR67-WF-P-001	Water Fountain	0.0100	Passed	0.0020	Passed	
Digby Regional High School	DR68-CF-P-001	Classroom Faucet	0.0990	Passed	0.0020	Passed	
Digby Regional High School	DR69-CS-P-001	Custodial Sink	0.0730	Passed	0.0030	Passed	
Digby Regional High School	DR6-BF-P-001	Bathroom Faucet	0.0740	Passed	-	Passed	
Digby Regional High School	DR70-CS-P-002	Custodial Sink	0.1240	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR71-BF-P-002	Bathroom Faucet	0.0800	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR72-CS-P-002	Custodial Sink	0.2340	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR73-CS-P-002	Custodial Sink	0.1640	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR74-CS-P-002	Custodial Sink	0.1260	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR75-CS-P-002	Custodial Sink	0.1910	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR76-WF-P-002	Water Fountain	0.0060	Passed	0.0020	Passed	
Digby Regional High School	DR77-BF-P-002	Bathroom Faucet	0.0780	Passed	0.0040	Passed	
Digby Regional High School	DR78-CF-P-002	Classroom Faucet	0.1150	Passed	0.0050	Passed	
Digby Regional High School	DR79-BF-P-002	Bathroom Faucet	0.0800	Passed	0.0040	Passed	
Digby Regional High School	DR7-BF-P-001	Bathroom Faucet	0.0550	Passed	-	Passed	
Digby Regional High School	DR81-BF-P-002	Bathroom Faucet	0.1880	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR82-BF-P-002	Bathroom Faucet	0.1260	Passed	0.0050	Passed	
Digby Regional High School	DR83-CF-P-002	Classroom Faucet	0.1150	Passed	0.0050	Passed	
Digby Regional High School	DR84-CF-P-002	Classroom Faucet	0.1250	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR85-CF-P-002	Classroom Faucet	0.1300	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR86-CF-P-002	Classroom Faucet	0.1680	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR87-CF-P-002	Classroom Faucet	0.1040	Passed	0.0050	Passed	
Digby Regional High School	DR88-CF-P-002	Classroom Faucet	0.1320	Passed	0.0040	Passed	
Digby Regional High School	DR89-CS-P-002	Custodial Sink	0.0640	Passed	0.0040	Passed	
Digby Regional High School	DR8-BF-P-001	Bathroom Faucet	0.0680	Passed	-	Passed	
Digby Regional High School	DR90-BF-P-002	Bathroom Faucet	2.1280	Exceeds Limit	0.0620	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR91-BF-P-002	Bathroom Faucet	1.4780	Passed	0.0500	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR92-BF-P-002	Bathroom Faucet	0.7270	Passed	0.0410	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR93-BF-P-002	Bathroom Faucet	0.0090	Passed	0.0020	Passed	
Digby Regional High School	DR94-BF-P-002	Bathroom Faucet	0.1300	Passed	0.0050	Passed	
Digby Regional High School	DR95-BF-P-002	Bathroom Faucet	0.1300	Passed	0.0050	Passed	
Digby Regional High School	DR96-BF-P-002	Bathroom Faucet	0.2600	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Digby Regional High School	DR97-BF-P-002	Bathroom Faucet	0.0720	Passed	-	Passed	
Digby Regional High School	DR98-BF-P-002	Bathroom Faucet	0.0530	Passed	-	Passed	
Digby Regional High School	DR99-SF-P-002	Staff Faucet	0.0520	Passed	0.0020	Passed	
Digby Regional High School	DR9-WF-P-001	Water Fountain	0.0010	Passed	-	Passed	
Digby Regional High School	DST1-BF-P-001	Bathroom Faucet	0.0240	Passed	0.0010	Passed	

Digby Regional High School	DST2-WF-P-001	Water Fountain	0.0100	Passed	0.0040	Passed	
Digby Regional High School	DST3-CS-P-001	Custodial Sink	0.0020	Passed	0.0010	Passed	
Drumlin Heights Consolidated School	D1 - BF - P - 001	Bathroom Faucet	0.0320	Passed	0.0007	Passed	
Drumlin Heights Consolidated School	D10 - CF - P - 001	Classroom Faucet	0.0780	Passed	0.0290	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D11 - BF - P - 001	Bathroom Faucet	0.0190	Passed	0.0007	Passed	
Drumlin Heights Consolidated School	D12 - BF - P - 001	Bathroom Faucet	0.0210	Passed	-	Passed	
Drumlin Heights Consolidated School	D13 - BF - P - 001	Bathroom Faucet	0.0300	Passed	-	Passed	
Drumlin Heights Consolidated School	D14 - BF - P - 001	Bathroom Faucet	0.0190	Passed	0.0014	Passed	
Drumlin Heights Consolidated School	D15 - BF - P - 001	Bathroom Faucet	0.0220	Passed	0.0029	Passed	
Drumlin Heights Consolidated School	D16 - BF - P - 001	Bathroom Faucet	0.0190	Passed	0.0007	Passed	
Drumlin Heights Consolidated School	D17 - KF - P - 001	Kitchen Faucet	0.0190	Passed	0.0014	Passed	
Drumlin Heights Consolidated School	D18 - KF - P - 001	Kitchen Faucet	0.0180	Passed	0.0011	Passed	
Drumlin Heights Consolidated School	D19 - KF - P - 001	Kitchen Faucet	0.0130	Passed	-	Passed	
Drumlin Heights Consolidated School	D2 - BF - P - 001	Bathroom Faucet	0.0290	Passed	0.0009	Passed	
Drumlin Heights Consolidated School	D20 - KF - P - 001	Kitchen Faucet	0.0170	Passed	0.0052	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Drumlin Heights Consolidated School	D21 - CF - P - 001	Classroom Faucet	0.0230	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D22 - BF - P - 001	Bathroom Faucet	0.0180	Passed	-	Passed	
Drumlin Heights Consolidated School	D23 - CF - P - 001	Classroom Faucet	0.0210	Passed	0.0035	Passed	
Drumlin Heights Consolidated School	D24 - WF - P - 001	Water Fountain	0.0076	Passed	-	Passed	
Drumlin Heights Consolidated School	D25 - BF - P - 001	Bathroom Faucet	0.0260	Passed	0.0013	Passed	
Drumlin Heights Consolidated School	D26 - BF - P - 001	Bathroom Faucet	0.0200	Passed	0.0018	Passed	
Drumlin Heights Consolidated School	D27 - BF - P - 001	Bathroom Faucet	0.0180	Passed	-	Passed	
Drumlin Heights Consolidated School	D28 - BF - P - 001	Bathroom Faucet	0.0140	Passed	-	Passed	
Drumlin Heights Consolidated School	D29 - BF - P - 001	Bathroom Faucet	0.0270	Passed	0.0006	Passed	
Drumlin Heights Consolidated School	D3 - BF - P - 001	Bathroom Faucet	0.1300	Passed	0.0068	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D30 - BF - P - 001	Bathroom Faucet	0.0270	Passed	-	Passed	
Drumlin Heights Consolidated School	D31 - BF - P - 001	Bathroom Faucet	0.0180	Passed	-	Passed	
Drumlin Heights Consolidated School	D32 - BF - P - 001	Bathroom Faucet	0.0170	Passed	-	Passed	
Drumlin Heights Consolidated School	D33 - BF - P - 001	Bathroom Faucet	0.0170	Passed	0.0006	Passed	
Drumlin Heights Consolidated School	D34 - BF - P - 001	Bathroom Faucet	0.0140	Passed	-	Passed	
Drumlin Heights Consolidated School	D35 - CF - P - 001	Classroom Faucet	0.0290	Passed	0.0022	Passed	
Drumlin Heights Consolidated School	D36 - BF - P - 001	Bathroom Faucet	0.0170	Passed	0.0006	Passed	
Drumlin Heights Consolidated School	D37 - CF - P - 001	Classroom Faucet	0.0180	Passed	0.0022	Passed	
Drumlin Heights Consolidated School	D38 - CF - P - 001	Classroom Faucet	0.0150	Passed	0.0018	Passed	
Drumlin Heights Consolidated School	D39 - CF - P - 001	Classroom Faucet	0.0170	Passed	0.0050	Passed	
Drumlin Heights Consolidated School	D4 - BF - P - 001	Bathroom Faucet	0.0210	Passed	0.0009	Passed	
Drumlin Heights Consolidated School	D40 - CF - P - 001	Classroom Faucet	0.0240	Passed	0.0022	Passed	
Drumlin Heights Consolidated School	D41 - CF - P - 001	Classroom Faucet	0.0210	Passed	0.0026	Passed	
Drumlin Heights Consolidated School	D42 - CF - P - 001	Classroom Faucet	0.0170	Passed	0.0019	Passed	
Drumlin Heights Consolidated School	D43 - BF - P - 001	Bathroom Faucet	0.0210	Passed	-	Passed	
Drumlin Heights Consolidated School	D44 - WF - P - 001	Water Fountain	0.0140	Passed	-	Passed	
Drumlin Heights Consolidated School	D45 - BF - P - 001	Bathroom Faucet	0.0170	Passed	-	Passed	
Drumlin Heights Consolidated School	D46 - BF - P - 001	Bathroom Faucet	0.0180	Passed	-	Passed	
Drumlin Heights Consolidated School	D47 - SF - P - 001	Staff Faucet	0.0150	Passed	-	Passed	
Drumlin Heights Consolidated School	D48 - WF - P - 001	Water Fountain	0.0064	Passed	-	Passed	
Drumlin Heights Consolidated School	D49 - BF - P - 001	Bathroom Faucet	0.0270	Passed	0.0015	Passed	
Drumlin Heights Consolidated School	D5 - BF - P - 001	Bathroom Faucet	0.0480	Passed	0.0012	Passed	
Drumlin Heights Consolidated School	D50 - BF - P - 001	Bathroom Faucet	0.0220	Passed	0.0017	Passed	
Drumlin Heights Consolidated School	D51 - BF - P - 001	Bathroom Faucet	0.0190	Passed	0.0005	Passed	
Drumlin Heights Consolidated School	D52 - BF - P - 001	Bathroom Faucet	0.0190	Passed	0.0006	Passed	
Drumlin Heights Consolidated School	D53 - BF - P - 001	Bathroom Faucet	0.0220	Passed	0.0046	Passed	
Drumlin Heights Consolidated School	D54 - BF - P - 001	Bathroom Faucet	0.0190	Passed	-	Passed	

Drumlin Heights Consolidated School	D55 - BF - P - 001	Bathroom Faucet	0.0170	Passed	-	Passed	
Drumlin Heights Consolidated School	D56 - BF - P - 001	Bathroom Faucet	0.0170	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D57 - BF - P - 001	Bathroom Faucet	0.0200	Passed	-	Passed	
Drumlin Heights Consolidated School	D59 - CF - P - 001	Classroom Faucet	0.0210	Passed	0.0007	Passed	
Drumlin Heights Consolidated School	D6 - BF - P - 001	Bathroom Faucet	0.0200	Passed	0.0006	Passed	
Drumlin Heights Consolidated School	D60 - CF - P - 001	Classroom Faucet	0.0160	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D61 - CF - P - 001	Classroom Faucet	0.0190	Passed	0.0021	Passed	
Drumlin Heights Consolidated School	D62 - CF - P - 001	Classroom Faucet	0.0190	Passed	0.0019	Passed	
Drumlin Heights Consolidated School	D63 - CF - P - 001	Classroom Faucet	0.0170	Passed	0.0044	Passed	
Drumlin Heights Consolidated School	D64 - CF - P - 001	Classroom Faucet	0.0230	Passed	0.0052	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D65 - WF - P - 002	Water Fountain	0.0091	Passed	-	Passed	
Drumlin Heights Consolidated School	D66 - BF - P - 002	Bathroom Faucet	0.0490	Passed	0.0050	Passed	
Drumlin Heights Consolidated School	D67 - BF - P - 002	Bathroom Faucet	0.0240	Passed	0.0036	Passed	
Drumlin Heights Consolidated School	D68 - BF - P - 002	Bathroom Faucet	0.0190	Passed	-	Passed	
Drumlin Heights Consolidated School	D69 - BS - P - 002		0.0190	Passed	0.0054	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D7 - BF - P - 001	Bathroom Faucet	1.1000	Passed	0.0430	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D70 - BF - P - 002	Bathroom Faucet	0.0220	Passed	0.0028	Passed	
Drumlin Heights Consolidated School	D71 - BF - P - 002	Bathroom Faucet	0.0240	Passed	0.0020	Passed	
Drumlin Heights Consolidated School	D72 - BF - P - 002	Bathroom Faucet	0.0210	Passed	0.0005	Passed	
Drumlin Heights Consolidated School	D73 - BF - P - 002	Bathroom Faucet	0.0200	Passed	0.0005	Passed	
Drumlin Heights Consolidated School	D74 - BF - P - 002	Bathroom Faucet	0.0210	Passed	0.0043	Passed	
Drumlin Heights Consolidated School	D75.1 - CF - P - 002	Classroom Faucet	0.0590	Passed	0.0250	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D77 - CF - P - 002	Classroom Faucet	0.0680	Passed	0.0150	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D78 - CF - P - 002	Classroom Faucet	0.0440	Passed	0.0033	Passed	
Drumlin Heights Consolidated School	D79 - CF - P - 002	Classroom Faucet	0.0340	Passed	0.0058	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D8 - BF - P - 001	Bathroom Faucet	0.0180	Passed	0.0006	Passed	
Drumlin Heights Consolidated School	D80 - CF - P - 002	Classroom Faucet	0.3000	Passed	0.0450	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D81 - CF - P - 002	Classroom Faucet	1.6000	Passed	0.0210	Exceeds Limit	Signage to be added to instruct handwashing only
Drumlin Heights Consolidated School	D9 - WF - P - 001	Water Fountain	0.0085	Passed	-	Passed	
Evelyn Richardson Memorial Elementary School	E1 - KF - P - 001	Kitchen Faucet	1.8000	Passed	0.0290	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Evelyn Richardson Memorial Elementary School	E10 - BF - P - 001	Bathroom Faucet	6.5000	Exceeds Limit	0.0066	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E11 - BF - P - 001	Bathroom Faucet	6.0000	Exceeds Limit	0.0057	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E12 - BF - P - 001	Bathroom Faucet	6.3000	Exceeds Limit	0.0092	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E13 - BF - P - 001	Bathroom Faucet	5.5000	Exceeds Limit	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E14 - BF - P - 001	Bathroom Faucet	6.0000	Exceeds Limit	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E15 - BF - P - 001	Bathroom Faucet	4.0000	Exceeds Limit	0.0073	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E16 - BF - P - 001	Bathroom Faucet	5.3000	Exceeds Limit	0.0029	Passed	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E17 - CS - P - 001	Custodial Sink	4.1000	Exceeds Limit	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E18 - WF - P - 001	Water Fountain	0.9200	Passed	-	Passed	
Evelyn Richardson Memorial Elementary School	E19 - BF - P - 001	Bathroom Faucet	2.2000	Exceeds Limit	0.0062	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E2 - KF - P - 001	Kitchen Faucet	3.5000	Exceeds Limit	0.0066	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Evelyn Richardson Memorial Elementary School	E20 - BF - P - 001	Bathroom Faucet	5.8000	Exceeds Limit	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E21 - BF - P - 001	Bathroom Faucet	7.2000	Exceeds Limit	0.0045	Passed	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E22 - BF - P - 001	Bathroom Faucet	6.7000	Exceeds Limit	0.0008	Passed	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E23 - CF - P - 001	Classroom Faucet	4.2000	Exceeds Limit	0.1600	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E24 - CS - P - 001	Custodial Sink	7.7000	Exceeds Limit	0.2600	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E25 - SF - P - 001	Staff Faucet	6.8000	Exceeds Limit	0.0230	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Evelyn Richardson Memorial Elementary School	E26 - BF - P - 001	Bathroom Faucet	3.8000	Exceeds Limit	0.0021	Passed	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E27 - BF - P - 001	Bathroom Faucet	5.2000	Exceeds Limit	0.0051	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E28 - WF - P - 001	Water Fountain	6.4000	Exceeds Limit	0.0160	Exceeds Limit	Fountain to be decommissioned, remediated, and retested. Other sources available
Evelyn Richardson Memorial Elementary School	E28 - WF - P - 001	Water Fountain	0.0120	Passed	-	Passed	
Evelyn Richardson Memorial Elementary School	E3 - KF - P - 001	Kitchen Faucet	2.8000	Exceeds Limit	0.0041	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available

Evelyn Richardson Memorial Elementary School	E4 - BF - P - 001	Bathroom Faucet	4.9000	Exceeds Limit	0.0310	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E5 - BF - P - 001	Bathroom Faucet	5.8000	Exceeds Limit	0.0390	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E6 - WF - P - 001	Water Fountain	5.7000	Exceeds Limit	0.0095	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Evelyn Richardson Memorial Elementary School	E7 - BF - P - 001	Bathroom Faucet	3.0000	Exceeds Limit	0.0290	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E8 - BF - P - 001	Bathroom Faucet	5.6000	Exceeds Limit	0.0093	Exceeds Limit	Signage to be added to instruct handwashing only
Evelyn Richardson Memorial Elementary School	E9 - BF - P - 001	Bathroom Faucet	5.6000	Exceeds Limit	0.0073	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR10-BF-P-001	Bathroom Faucet	0.3230	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR11-BF-P-001	Bathroom Faucet	0.3570	Passed	0.0050	Passed	
Forest Ridge Academy	FR12-BF-P-001	Bathroom Faucet	0.4270	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR13-WF-P-001	Water Fountain	0.0880	Passed	0.0060	Exceeds Limit	Fountain to be decommissioned, remediated, and retested. Other sources available
Forest Ridge Academy	FR14-BF-P-001	Bathroom Faucet	0.2300	Passed	0.0050	Passed	
Forest Ridge Academy	FR15-BF-P-001	Bathroom Faucet	0.4090	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR16.1-BF-P-001	Bathroom Faucet	0.2300	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR16-BF-P-001	Bathroom Faucet	0.2710	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR17-BF-P-001	Bathroom Faucet	0.3270	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR18-SF-P-001	Staff Faucet	0.2160	Passed	0.0080	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Forest Ridge Academy	FR19.1-BF-P-001	Bathroom Faucet	0.2180	Passed	0.0040	Passed	
Forest Ridge Academy	FR19-BF-P-001	Bathroom Faucet	0.2070	Passed	0.0050	Passed	
Forest Ridge Academy	FR1-CS-P-001	Custodial Sink	0.0450	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR20-CF-P-001	Classroom Faucet	0.4250	Passed	0.0440	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR21-CS-P-001	Custodial Sink	0.2380	Passed	0.0050	Passed	
Forest Ridge Academy	FR22-WF-P-001	Water Fountain	0.0400	Passed	0.0050	Passed	
Forest Ridge Academy	FR23-CF-P-001	Classroom Faucet	0.4270	Passed	0.0220	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR24-BF-P-001	Bathroom Faucet	0.2200	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR25-CF-P-001	Classroom Faucet	0.2360	Passed	0.0420	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR26-BF-P-001	Bathroom Faucet	0.2600	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR27-CF-P-001	Classroom Faucet	0.3930	Passed	0.0570	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR28-CF-P-001	Classroom Faucet	0.5140	Passed	0.0420	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR29-CF-P-001	Classroom Faucet	0.2210	Passed	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR2-CF-P-001	Classroom Faucet	2.1700	Exceeds Limit	0.0280	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR30-CF-P-001	Classroom Faucet	0.3610	Passed	0.1200	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR31-BF-P-001	Bathroom Faucet	0.1950	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR32-BF-P-001	Bathroom Faucet	0.3310	Passed	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR33-BF-P-001	Bathroom Faucet	0.2500	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR34-WF-P-001	Water Fountain	0.1200	Passed	0.0050	Passed	
Forest Ridge Academy	FR35-BF-P-001	Bathroom Faucet	0.2520	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR36-BF-P-001	Bathroom Faucet	0.2420	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR37-BF-P-001	Bathroom Faucet	0.1910	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR38-BF-P-001	Bathroom Faucet	0.4390	Passed	0.0190	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR39-BF-P-001	Bathroom Faucet	0.2250	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR3-CF-P-001	Classroom Faucet	0.6550	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR4.1-CF-P-001	Classroom Faucet	0.7780	Passed	0.0450	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR40-CS-P-001	Custodial Sink	0.1070	Passed	0.0450	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Forest Ridge Academy	FR41-KF-P-001	Kitchen Faucet	0.2920	Passed	0.0420	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Forest Ridge Academy	FR42-KF-P-001	Kitchen Faucet	0.1510	Passed	0.0360	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Forest Ridge Academy	FR43.1-KF-P-001	Kitchen Faucet	0.4950	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR43-KF-P-001	Kitchen Faucet	0.1740	Passed	0.0770	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR4-CF-P-001	Classroom Faucet	3.1170	Exceeds Limit	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR5-CF-P-001	Classroom Faucet	0.5020	Passed	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR6-CF-P-001	Classroom Faucet	0.6450	Passed	0.0180	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR7-CF-P-001	Classroom Faucet	0.3610	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Forest Ridge Academy	FR8-BF-P-001	Bathroom Faucet	0.2550	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only

Forest Ridge Academy	FR9-CF-P-001	Classroom Faucet	0.7260	Passed	0.0270	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H1 - BF - P - 001	Bathroom Faucet	0.0780	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H10 - KF - P - 001	Kitchen Faucet	0.0970	Passed	-	Passed	
Hillcrest Academy	H11 - KF - P - 001	Kitchen Faucet	0.0600	Passed	0.0008	Passed	
Hillcrest Academy	H12 - BF - P - 001	Bathroom Faucet	0.0660	Passed	0.0020	Passed	
Hillcrest Academy	H13 - CF - P - 001	Classroom Faucet	0.0900	Passed	0.0041	Passed	
Hillcrest Academy	H14 - CF - P - 001	Classroom Faucet	0.2300	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H15 - BF - P - 001	Bathroom Faucet	0.0530	Passed	0.0021	Passed	
Hillcrest Academy	H16 - CF - P - 001	Classroom Faucet	0.0770	Passed	0.0039	Passed	
Hillcrest Academy	H17 - BF - P - 001	Bathroom Faucet	0.0390	Passed	0.0022	Passed	
Hillcrest Academy	H18 - CF - P - 001	Classroom Faucet	0.0750	Passed	0.0036	Passed	
Hillcrest Academy	H19 - WF - P - 001	Water Fountain	0.0150	Passed	0.0007	Passed	
Hillcrest Academy	H19 - WF - P - 001	Water Fountain	0.1400	Passed	0.0071	Exceeds Limit	Fountain to be decommissioned, remediated, and retested. Other sources available
Hillcrest Academy	H2 - BF - P - 001	Bathroom Faucet	0.0690	Passed	0.0013	Passed	
Hillcrest Academy	H20 - CF - P - 001	Classroom Faucet	0.1100	Passed	0.0075	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H21 - BF - P - 001	Bathroom Faucet	0.2100	Passed	0.0057	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H22 - BF - P - 001	Bathroom Faucet	0.1100	Passed	0.0035	Passed	
Hillcrest Academy	H23 - BF - P - 001	Bathroom Faucet	0.0870	Passed	0.0009	Passed	
Hillcrest Academy	H24 - BF - P - 001	Bathroom Faucet	0.0760	Passed	0.0014	Passed	
Hillcrest Academy	H25 - SF - P - 001	Staff Faucet	0.0700	Passed	0.0012	Passed	
Hillcrest Academy	H26 - BF - P - 001	Bathroom Faucet	0.1400	Passed	0.0042	Passed	
Hillcrest Academy	H27 - CF - P - 001	Classroom Faucet	0.1900	Passed	0.0280	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H28 - BF - P - 001	Bathroom Faucet	0.0550	Passed	0.0017	Passed	
Hillcrest Academy	H29 - BF - P - 001	Bathroom Faucet	0.1300	Passed	0.0026	Passed	
Hillcrest Academy	H3 - BF - P - 001	Bathroom Faucet	0.0790	Passed	0.0049	Passed	
Hillcrest Academy	H30 - CF - P - 001	Classroom Faucet	0.1000	Passed	0.0032	Passed	
Hillcrest Academy	H32 - CF - P - 001	Classroom Faucet	0.0920	Passed	0.1300	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H33 - CF - P - 001	Classroom Faucet	0.0360	Passed	0.0020	Passed	
Hillcrest Academy	H34 - BF - P - 002	Bathroom Faucet	0.0850	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H35 - BF - P - 002	Bathroom Faucet	0.0550	Passed	0.0047	Passed	
Hillcrest Academy	H36 - BF - P - 002	Bathroom Faucet	0.0390	Passed	0.0032	Passed	
Hillcrest Academy	H37 - CS - P - 002	Custodial Sink	0.0770	Passed	0.0024	Passed	
Hillcrest Academy	H38 - BF - P - 002	Bathroom Faucet	0.0740	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Hillcrest Academy	H39 - BF - P - 002	Bathroom Faucet	0.0820	Passed	0.0011	Passed	
Hillcrest Academy	H4 - BF - P - 001	Bathroom Faucet	0.0600	Passed	0.0006	Passed	
Hillcrest Academy	H40 - BF - P - 002	Bathroom Faucet	0.0860	Passed	0.0012	Passed	
Hillcrest Academy	H41 - BF - P - 002	Bathroom Faucet	0.0600	Passed	0.0006	Passed	
Hillcrest Academy	H42 - WF - P - 002	Water Fountain	0.1400	Passed	-	Passed	
Hillcrest Academy	H5 - BF - P - 001	Bathroom Faucet	0.0810	Passed	0.0009	Passed	
Hillcrest Academy	H6 - BF - P - 001	Bathroom Faucet	0.0610	Passed	0.0025	Passed	
Hillcrest Academy	H7 - CS - P - 001	Custodial Sink	0.0190	Passed	0.0035	Passed	
Hillcrest Academy	H9 - KF - P - 001	Kitchen Faucet	0.0710	Passed	0.0032	Passed	
Islands Consolidated School	IC10-CF-P-001	Classroom Faucet	0.0160	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC11-CF-P-001	Classroom Faucet	0.0160	Passed	0.0030	Passed	
Islands Consolidated School	IC12-KF-P-001	Kitchen Faucet	0.0080	Passed	0.0010	Passed	
Islands Consolidated School	IC13-KF-P-001	Kitchen Faucet	0.0040	Passed	0.0010	Passed	
Islands Consolidated School	IC14-KF-P-001	Kitchen Faucet	0.0040	Passed	0.0010	Passed	
Islands Consolidated School	IC16-BF-P-001	Bathroom Faucet	0.0220	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC17-BF-P-001	Bathroom Faucet	0.0110	Passed	0.0020	Passed	
Islands Consolidated School	IC18-BF-P-001	Bathroom Faucet	0.0140	Passed	0.0010	Passed	
Islands Consolidated School	IC19-BF-P-001	Bathroom Faucet	0.0120	Passed	0.0020	Passed	
Islands Consolidated School	IC1-SF-P-001	Staff Faucet	0.0140	Passed	0.0030	Passed	

Islands Consolidated School	IC20-BF-P-001	Bathroom Faucet	0.0140	Passed	0.0030	Passed	
Islands Consolidated School	IC21-CF-P-001	Classroom Faucet	0.0090	Passed	0.0020	Passed	
Islands Consolidated School	IC23-WF-P-001	Water Fountain	0.0470	Passed	0.0010	Passed	
Islands Consolidated School	IC24-CF-P-001	Classroom Faucet	0.0190	Passed	0.0030	Passed	
Islands Consolidated School	IC25-CF-P-001	Classroom Faucet	0.0200	Passed	0.0040	Passed	
Islands Consolidated School	IC26-CF-P-001	Classroom Faucet	0.0220	Passed	0.0050	Passed	
Islands Consolidated School	IC27-CF-P-001	Classroom Faucet	0.0220	Passed	0.0030	Passed	
Islands Consolidated School	IC28-CF-P-001	Classroom Faucet	0.0310	Passed	0.0240	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC29-CF-P-001	Classroom Faucet	0.0390	Passed	0.0680	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC2-BF-P-001	Bathroom Faucet	0.0160	Passed	0.0050	Passed	
Islands Consolidated School	IC30.1-CS-P-001	Custodial Sink	0.0130	Passed	0.0030	Passed	
Islands Consolidated School	IC30-CS-P-001	Custodial Sink	0.0990	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC32-BF-P-001	Bathroom Faucet	0.0180	Passed	0.0030	Passed	
Islands Consolidated School	IC34-BF-P-001	Bathroom Faucet	0.0180	Passed	0.0040	Passed	
Islands Consolidated School	IC35-WF-P-001	Water Fountain	0.0220	Passed	0.0010	Passed	
Islands Consolidated School	IC36-BF-P-001	Bathroom Faucet	0.0170	Passed	0.0050	Passed	
Islands Consolidated School	IC3-BF-P-001	Bathroom Faucet	0.0120	Passed	0.0040	Passed	
Islands Consolidated School	IC4-BF-P-001	Bathroom Faucet	0.0190	Passed	0.0030	Passed	
Islands Consolidated School	IC5.1-WF-P-001	Water Fountain	0.0770	Passed	0.0010	Passed	
Islands Consolidated School	IC5-CS-P-001	Custodial Sink	0.1520	Passed	0.0200	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC6-BF-P-001	Bathroom Faucet	0.0160	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC7-BF-P-001	Bathroom Faucet	0.0160	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Islands Consolidated School	IC8-BF-P-001	Bathroom Faucet	0.0130	Passed	0.0040	Passed	
Islands Consolidated School	IC9-CF-P-001	Classroom Faucet	0.0130	Passed	0.0040	Passed	
Lockeport Elementary School	LE1 - KF - P - 001	Kitchen Faucet	0.3000	Passed	0.0043	Passed	
Lockeport Elementary School	LE10 - BF - P - 001	Bathroom Faucet	0.1600	Passed	0.0011	Passed	
Lockeport Elementary School	LE11 - BF - P - 001	Bathroom Faucet	0.2700	Passed	0.0075	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Elementary School	LE12 - BF - P - 001	Bathroom Faucet	0.4600	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Elementary School	LE13 - BF - P - 001	Bathroom Faucet	0.1600	Passed	0.0027	Passed	
Lockeport Elementary School	LE14 - BF - P - 001	Bathroom Faucet	0.2300	Passed	0.0028	Passed	
Lockeport Elementary School	LE15 - BF - P - 001	Bathroom Faucet	0.3400	Passed	0.0041	Passed	
Lockeport Elementary School	LE16 - CF - P - 001	Classroom Faucet	0.1700	Passed	0.0012	Passed	
Lockeport Elementary School	LE17 - BF - P - 001	Bathroom Faucet	0.1700	Passed	0.0021	Passed	
Lockeport Elementary School	LE18 - WF -P-001	Water Fountain	0.1000	Passed	-	Passed	
Lockeport Elementary School	LE2 - KF - P - 001	Kitchen Faucet	0.4800	Passed	0.0042	Passed	
Lockeport Elementary School	LE3 - KF - P - 001	Kitchen Faucet	0.2700	Passed	0.0044	Passed	
Lockeport Elementary School	LE4 - KF - P - 001	Kitchen Faucet	0.1400	Passed	0.0055	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Lockeport Elementary School	LE5 - KF - P - 001	Kitchen Faucet	0.0011	Passed	-	Passed	
Lockeport Elementary School	LE6 - BF - P - 001	Bathroom Faucet	0.0830	Passed	0.0011	Passed	
Lockeport Elementary School	LE7 - CS - P - 001	Custodial Sink	0.2300	Passed	0.0028	Passed	
Lockeport Elementary School	LE8 - SF - P - 001	Staff Faucet	0.2600	Passed	0.0058	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Lockeport Elementary School	LE9 - SF - P - 001	Staff Faucet	0.0110	Passed	0.0076	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Lockeport Regional High School	LH10-KF-P-001	Kitchen Faucet	0.5960	Passed	0.0180	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Lockeport Regional High School	LH11-BF-P-001	Bathroom Faucet	0.5400	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH12-BF-P-001	Bathroom Faucet	0.5330	Passed	0.0280	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH13-BF-P-001	Bathroom Faucet	0.3300	Passed	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH14-CS-P-001	Custodial Sink	0.8910	Passed	0.0550	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH15-BF-P-001	Bathroom Faucet	0.3130	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH16-BF-P-001	Bathroom Faucet	0.5140	Passed	0.0300	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH17-BF-P-001	Bathroom Faucet	0.5950	Passed	0.0420	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH18-WF-P-002	Water Fountain	1.9530	Passed	0.0010	Passed	
Lockeport Regional High School	LH19-CF-P-002	Classroom Faucet	0.7640	Passed	0.0290	Exceeds Limit	Signage to be added to instruct handwashing only

Lockeport Regional High School	LH1-KF-P-001	Kitchen Faucet	0.3730	Passed	0.0470	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Lockeport Regional High School	LH2.1-SF-P-001	Staff Faucet	0.0800	Passed	0.0100	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Lockeport Regional High School	LH20-CF-P-002	Classroom Faucet	0.7660	Passed	0.0380	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH21-BF-P-002	Bathroom Faucet	0.4570	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH22-BF-P-002	Bathroom Faucet	0.5570	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH23-BF-P-002	Bathroom Faucet	0.5380	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH2-KF-P-001	Kitchen Faucet	0.3750	Passed	0.0130	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Lockeport Regional High School	LH3.1-CF-P-001	Classroom Faucet	0.0700	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH3.2-CF-P-001	Classroom Faucet	0.0870	Passed	0.0790	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH3.3-CF-P-001	Classroom Faucet	0.0390	Passed	0.0050	Passed	
Lockeport Regional High School	LH3-WF-P-001	Water Fountain	0.4350	Passed	0.0010	Passed	
Lockeport Regional High School	LH4.1-BF-P-001	Bathroom Faucet	0.9400	Passed	0.0330	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH4-CS-P-001	Custodial Sink	0.4450	Passed	0.0490	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH5-BF-P-001	Bathroom Faucet	0.7000	Passed	0.0200	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH6-BF-P-001	Bathroom Faucet	0.6770	Passed	0.0180	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH7-BF-P-001	Bathroom Faucet	0.7550	Passed	0.0240	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH8-BF-P-001	Bathroom Faucet	0.2120	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Lockeport Regional High School	LH9-BF-P-001	Bathroom Faucet	0.4370	Passed	0.0180	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG10-CF-P-001	Classroom Faucet	0.2260	Passed	0.0750	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG11-BF-P-001	Bathroom Faucet	0.2350	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG12-BF-P-001	Bathroom Faucet	0.2440	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG13-CF-P-001	Classroom Faucet	0.3120	Passed	0.0390	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG14-CF-P-001	Classroom Faucet	0.3380	Passed	0.0790	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG15-CF-P-001	Classroom Faucet	0.3230	Passed	0.0150	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG16-CF-P-001	Classroom Faucet	0.3780	Passed	0.0040	Passed	
Maple Grove Education Centre	MG17-WF-P-001	Water Fountain	0.2360	Passed	0.0040	Passed	
Maple Grove Education Centre	MG18-CS-P-001	Custodial Sink	0.2050	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG19-BF-P-001	Bathroom Faucet	0.5430	Passed	0.0040	Passed	
Maple Grove Education Centre	MG1-BF-P-001	Bathroom Faucet	0.2590	Passed	0.0220	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG20-BF-P-001	Bathroom Faucet	0.3480	Passed	0.0230	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG21-BF-P-001	Bathroom Faucet	1.2380	Passed	0.2130	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG22-BF-P-001	Bathroom Faucet	0.2630	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG23-BF-P-001	Bathroom Faucet	0.2590	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG24-BF-P-001	Bathroom Faucet	0.2820	Passed	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG25-BF-P-001	Bathroom Faucet	0.4360	Passed	0.0030	Passed	
Maple Grove Education Centre	MG26-BF-P-001	Bathroom Faucet	0.6110	Passed	0.0410	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG27-CS-P-001	Custodial Sink	0.4150	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG28-BF-P-001	Bathroom Faucet	0.2130	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG29-BF-P-001	Bathroom Faucet	0.1930	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG2-BF-P-001	Bathroom Faucet	0.5000	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG30.1 -KF-S -001	Kitchen Faucet	0.2910	Passed	0.0130	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG30.1-KF-P-001	Kitchen Faucet	0.7260	Passed	0.0560	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG30.2 -KF-S -001	Kitchen Faucet	0.2370	Passed	0.0060	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG30.2-KF-P-001	Kitchen Faucet	0.5930	Passed	0.0160	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG30-KF-P-001	Kitchen Faucet	0.4530	Passed	0.0050	Passed	
Maple Grove Education Centre	MG31 -KF -S -001	Kitchen Faucet	0.3740	Passed	0.0560	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG31-KF-P-001	Kitchen Faucet	0.3450	Passed	0.0380	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG32-CF-P-002	Classroom Faucet	0.3880	Passed	0.0050	Passed	
Maple Grove Education Centre	MG33-CF-P-002	Classroom Faucet	0.4160	Passed	0.0030	Passed	
Maple Grove Education Centre	MG34-BF-P-002	Bathroom Faucet	0.3870	Passed	0.0030	Passed	
Maple Grove Education Centre	MG35-BF-P-002	Bathroom Faucet	0.4330	Passed	0.0270	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG36-BF-P-002	Bathroom Faucet	0.3220	Passed	0.0250	Exceeds Limit	Signage to be added to instruct handwashing only

Maple Grove Education Centre	MG37-WF-P-002	Water Fountain	0.0810	Passed	-	Passed	
Maple Grove Education Centre	MG38-CS-P-002	Custodial Sink	0.3980	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG39-BF-P-002	Bathroom Faucet	0.4060	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG3-BF-P-001	Bathroom Faucet	0.1720	Passed	0.0140	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG40-BF-P-002	Bathroom Faucet	0.3570	Passed	0.0190	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG41-BF-P-002	Bathroom Faucet	0.3240	Passed	0.0160	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG42-CF-P-002	Classroom Faucet	0.3030	Passed	0.0040	Passed	
Maple Grove Education Centre	MG43-WF-P-002	Water Fountain	0.7660	Passed	0.0020	Passed	
Maple Grove Education Centre	MG44-BF-P-002	Bathroom Faucet	0.3130	Passed	0.0030	Passed	
Maple Grove Education Centre	MG45-BF-P-002	Bathroom Faucet	0.5300	Passed	0.0040	Passed	
Maple Grove Education Centre	MG46-CS-P-002	Custodial Sink	0.3270	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG47-BF-P-002	Bathroom Faucet	0.2300	Passed	0.0020	Passed	
Maple Grove Education Centre	MG48.1-CF-P-002	Classroom Faucet	0.2520	Passed	0.0150	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG48.2-CF-P-002	Classroom Faucet	0.1900	Passed	0.0730	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG48-BF-P-002	Bathroom Faucet	0.2210	Passed	0.0020	Passed	
Maple Grove Education Centre	MG49-CF-P-002	Classroom Faucet	0.5470	Passed	0.0650	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG4-WF-P-001	Water Fountain	0.4800	Passed	0.0010	Passed	
Maple Grove Education Centre	MG50-CF-P-002	Classroom Faucet	0.2840	Passed	0.0290	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG51-CF-P-002	Classroom Faucet	0.3910	Passed	0.0740	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG52-CF-P-002	Classroom Faucet	0.3240	Passed	0.0440	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG53-CF-P-002	Classroom Faucet	0.6080	Passed	0.0310	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG54-CF-P-002	Classroom Faucet	0.3850	Passed	0.0580	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG55-CF-P-002	Classroom Faucet	0.2640	Passed	0.0370	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG56-CF-P-002	Classroom Faucet	0.6600	Passed	0.0940	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG57-CF-P-002	Classroom Faucet	0.3060	Passed	0.0390	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG58-CF-P-002	Classroom Faucet	0.7340	Passed	0.0370	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG59-CF-P-002	Classroom Faucet	0.8070	Passed	0.0790	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG5-BF-P-001	Bathroom Faucet	0.2860	Passed	0.0030	Passed	
Maple Grove Education Centre	MG60 -KF -S -002	Kitchen Faucet	0.2570	Passed	0.0050	Passed	
Maple Grove Education Centre	MG60-CF-P-002	Classroom Faucet	0.3650	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG61 -KF-S -002	Kitchen Faucet	0.2500	Passed	0.0060	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG61-CF-P-002	Classroom Faucet	0.3790	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG62-CF-P-002	Classroom Faucet	0.3460	Passed	0.0050	Passed	
Maple Grove Education Centre	MG63 -KF-S - 002	Kitchen Faucet	0.2450	Passed	0.0040	Passed	
Maple Grove Education Centre	MG63-CF-P-002	Classroom Faucet	0.3640	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG64 -KF-S -002	Kitchen Faucet	0.2600	Passed	0.0110	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Grove Education Centre	MG64-CF-P-002	Classroom Faucet	0.4940	Passed	0.0210	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG65-CF-P-002	Classroom Faucet	0.3600	Passed	0.0320	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG6-BF-P-001	Bathroom Faucet	0.3320	Passed	0.0040	Passed	
Maple Grove Education Centre	MG7-CS-P-001	Custodial Sink	0.3550	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Maple Grove Education Centre	MG8-BF-P-001	Bathroom Faucet	0.2680	Passed	0.0030	Passed	
Maple Grove Education Centre	MG9-BF-P-001	Bathroom Faucet	0.3550	Passed	0.0050	Passed	
Meadowfields Community School	MF10-BF-P-001	Bathroom Faucet	0.1960	Passed	0.0010	Passed	
Meadowfields Community School	MF11-BF-P-001	Bathroom Faucet	0.1870	Passed	0.0010	Passed	
Meadowfields Community School	MF12-CF-P-001	Classroom Faucet	0.3500	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Meadowfields Community School	MF13-CF-P-001	Classroom Faucet	0.1750	Passed	0.0010	Passed	
Meadowfields Community School	MF15-KF-P-001	Kitchen Faucet	0.7150	Passed	0.0110	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Meadowfields Community School	MF16-KF-P-001	Kitchen Faucet	0.2660	Passed	0.0040	Passed	
Meadowfields Community School	MF17-KF-P-001	Kitchen Faucet	0.1310	Passed	0.0030	Passed	
Meadowfields Community School	MF18-BF-P-001	Bathroom Faucet	0.3420	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Meadowfields Community School	MF19-BF-P-001	Bathroom Faucet	0.2350	Passed	-	Passed	
Meadowfields Community School	MF1-CS-P-001	Custodial Sink	0.2480	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only

Meadowfields Community School	MF20-BF-P-001	Bathroom Faucet	0.1370	Passed	-	Passed
Meadowfields Community School	MF21-SF-P-001	Staff Faucet	0.2200	Passed	-	Passed
Meadowfields Community School	MF22-BF-P-001	Bathroom Faucet	0.2170	Passed	-	Passed
Meadowfields Community School	MF23-SF-P-001	Staff Faucet	0.1330	Passed	-	Passed
Meadowfields Community School	MF24-WF-P-001	Water Fountain	0.6360	Passed	-	Passed
Meadowfields Community School	MF25-BF-P-001	Bathroom Faucet	0.2360	Passed	-	Passed
Meadowfields Community School	MF26-BF-P-001	Bathroom Faucet	0.2670	Passed	-	Passed
Meadowfields Community School	MF27-CS-P-001	Custodial Sink	0.1100	Passed	0.0020	Passed
Meadowfields Community School	MF28-WF-P-001	Water Fountain	0.1330	Passed	-	Passed
Meadowfields Community School	MF29-BF-P-001	Bathroom Faucet	0.1890	Passed	-	Passed
Meadowfields Community School	MF2-BF-P-001	Bathroom Faucet	0.3440	Passed	0.0020	Passed
Meadowfields Community School	MF30-BF-P-001	Bathroom Faucet	0.1670	Passed	-	Passed
Meadowfields Community School	MF32-BF-P-001	Bathroom Faucet	0.3280	Passed	0.0010	Passed
Meadowfields Community School	MF33-BF-P-001	Bathroom Faucet	0.2040	Passed	-	Passed
Meadowfields Community School	MF34-BF-P-001	Bathroom Faucet	0.2030	Passed	-	Passed
Meadowfields Community School	MF35-BF-P-001	Bathroom Faucet	0.2010	Passed	-	Passed
Meadowfields Community School	MF37-CS-P-001	Custodial Sink	0.1410	Passed	0.0010	Passed
Meadowfields Community School	MF38.1-WF-P-001	Water Fountain	0.2280	Passed	-	Passed
Meadowfields Community School	MF38-CF-P-001	Classroom Faucet	0.1990	Passed	0.0020	Passed
Meadowfields Community School	MF39-BF-P-001	Bathroom Faucet	0.1730	Passed	-	Passed
Meadowfields Community School	MF3-BF-P-001	Bathroom Faucet	0.5560	Passed	0.0020	Passed
Meadowfields Community School	MF40.1-WF-P-001	Water Fountain	0.2220	Passed	-	Passed
Meadowfields Community School	MF40-CF-P-001	Classroom Faucet	0.2120	Passed	0.0010	Passed
Meadowfields Community School	MF41-BF-P-001	Bathroom Faucet	0.2250	Passed	-	Passed
Meadowfields Community School	MF42-BF-P-001	Bathroom Faucet	0.1890	Passed	0.0010	Passed
Meadowfields Community School	MF43.1-WF-P-001	Water Fountain	0.2990	Passed	-	Passed
Meadowfields Community School	MF43-CF-P-001	Classroom Faucet	0.2040	Passed	0.0010	Passed
Meadowfields Community School	MF44-BF-P-001	Bathroom Faucet	0.2020	Passed	-	Passed
Meadowfields Community School	MF45.1-WF-P-001	Water Fountain	0.2640	Passed	-	Passed
Meadowfields Community School	MF45-CF-P-001	Classroom Faucet	0.1820	Passed	0.0010	Passed
Meadowfields Community School	MF46-WF-P-001	Water Fountain	0.2110	Passed	0.0010	Passed
Meadowfields Community School	MF47-BF-P-001	Bathroom Faucet	0.1940	Passed	-	Passed
Meadowfields Community School	MF48-BF-P-001	Bathroom Faucet	0.2120	Passed	-	Passed
Meadowfields Community School	MF4-BF-P-001	Bathroom Faucet	0.6350	Passed	0.0010	Passed
Meadowfields Community School	MF50.1-WF-P-001	Water Fountain	0.3170	Passed	-	Passed
Meadowfields Community School	MF50-CF-P-001	Classroom Faucet	0.2060	Passed	0.0020	Passed
Meadowfields Community School	MF51-BF-P-001	Bathroom Faucet	0.2500	Passed	-	Passed
Meadowfields Community School	MF52.1-WF-P-001	Water Fountain	0.2870	Passed	-	Passed
Meadowfields Community School	MF52-CF-P-001	Classroom Faucet	0.1790	Passed	0.0010	Passed
Meadowfields Community School	MF53-BF-P-001	Bathroom Faucet	0.2240	Passed	0.0010	Passed
Meadowfields Community School	MF54-BF-P-001	Bathroom Faucet	0.2570	Passed	0.0020	Passed
Meadowfields Community School	MF55.1-WF-P-001	Water Fountain	0.3150	Passed	0.0010	Passed
Meadowfields Community School	MF55-CF-P-001	Classroom Faucet	0.2290	Passed	0.0020	Passed
Meadowfields Community School	MF56-BF-P-001	Bathroom Faucet	0.2210	Passed	0.0020	Passed
Meadowfields Community School	MF57.1-WF-P-001	Water Fountain	0.3080	Passed	-	Passed
Meadowfields Community School	MF57-CF-P-001	Classroom Faucet	0.2760	Passed	0.0010	Passed
Meadowfields Community School	MF58-CF-P-001	Classroom Faucet	0.0810	Passed	-	Passed
Meadowfields Community School	MF5-BF-P-001	Bathroom Faucet	0.3530	Passed	0.0010	Passed
Meadowfields Community School	MF6-BF-P-001	Bathroom Faucet	0.7370	Passed	0.0030	Passed
Meadowfields Community School	MF7-WF-P-001	Water Fountain	0.4330	Passed	0.0010	Passed
Meadowfields Community School	MF8-BF-P-001	Bathroom Faucet	0.2270	Passed	0.0010	Passed
Meadowfields Community School	MF9-BF-P-001	Bathroom Faucet	0.2060	Passed	0.0010	Passed

Plymouth School	PS10-BF-P-001	Bathroom Faucet	0.1030	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS11-BF-P-001	Bathroom Faucet	0.0890	Passed	0.0030	Passed	
Plymouth School	PS12-BF-P-001	Bathroom Faucet	0.1140	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS13-CS-P-001	Custodial Sink	0.3720	Passed	0.0330	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS14-BF-P-001	Bathroom Faucet	0.1020	Passed	0.0050	Passed	
Plymouth School	PS15-BF-P-001	Bathroom Faucet	0.2340	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS16-CF-P-001	Classroom Faucet	0.2370	Passed	0.0030	Passed	
Plymouth School	PS17-CF-P-001	Classroom Faucet	0.1020	Passed	0.0050	Passed	
Plymouth School	PS18-BF-P-001	Bathroom Faucet	0.3530	Passed	0.0320	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS19-BF-P-001	Bathroom Faucet	0.2070	Passed	0.0050	Passed	
Plymouth School	PS1-CS-P-001	Custodial Sink	0.0900	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS20-BF-P-001	Bathroom Faucet	0.2820	Passed	0.0120	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS21-BF-P-001	Bathroom Faucet	0.1330	Passed	0.0030	Passed	
Plymouth School	PS22-BF-P-001	Bathroom Faucet	0.1370	Passed	0.0040	Passed	
Plymouth School	PS23-WF-P-001	Water Fountain	0.0500	Passed	0.0020	Passed	
Plymouth School	PS24-BF-P-001	Bathroom Faucet	0.2120	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS25.1-BF-P-001	Bathroom Faucet	0.4750	Passed	0.0200	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS25-BF-P-001	Bathroom Faucet	0.1120	Passed	0.0050	Passed	
Plymouth School	PS26-CS-P-001	Custodial Sink	0.1510	Passed	0.0040	Passed	
Plymouth School	PS27-KF-P-001	Kitchen Faucet	0.1060	Passed	0.0040	Passed	
Plymouth School	PS28-SF-P-001	Staff Faucet	0.0880	Passed	0.0020	Passed	
Plymouth School	PS29flush-KF-F-001	Kitchen Faucet	0.0660	Passed	0.0020	Passed	
Plymouth School	PS29-KF-P-001	Kitchen Faucet	0.0760	Passed	0.0060	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Plymouth School	PS29-KF-S-001	Kitchen Faucet	0.1810	Passed	0.1260	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Plymouth School	PS2-WF-P-001	Water Fountain	0.1080	Passed	0.0010	Passed	
Plymouth School	PS30flush-KF-F-001	Kitchen Faucet	0.0600	Passed	0.0020	Passed	
Plymouth School	PS30-KF-P-001	Kitchen Faucet	0.1560	Passed	0.0090	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Plymouth School	PS30-KF-S-001	Kitchen Faucet	0.1730	Passed	0.0270	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Plymouth School	PS31-WF-P-001	Water Fountain	0.3890	Passed	0.0010	Passed	
Plymouth School	PS32-CF-P-001	Classroom Faucet	0.4240	Passed	0.0230	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS32-CF-S-001	Classroom Faucet	0.4140	Passed	0.0200	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS32flush-CF-F-001	Classroom Faucet	0.2660	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS33-BF-P-001	Bathroom Faucet	1.2440	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS3-BF-P-001	Bathroom Faucet	0.0380	Passed	0.0030	Passed	
Plymouth School	PS4-BF-P-001	Bathroom Faucet	0.1350	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS5-WF-P-001	Water Fountain	0.3990	Passed	0.0040	Passed	
Plymouth School	PS6-BF-P-001	Bathroom Faucet	0.1090	Passed	0.0110	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS7-WF-P-001	Water Fountain	0.2590	Passed	0.0010	Passed	
Plymouth School	PS8-CF-P-001	Classroom Faucet	0.1970	Passed	0.0080	Exceeds Limit	Signage to be added to instruct handwashing only
Plymouth School	PS9-CF-P-001	Classroom Faucet	0.1740	Passed	0.1740	Exceeds Limit	Signage to be added to instruct handwashing only
Port Maitland Consolidated School	PM1 - BF - P - 001	Bathroom Faucet	0.0080	Passed	0.0034	Passed	
Port Maitland Consolidated School	PM10 - BF - P - 001	Bathroom Faucet	0.0031	Passed	0.0012	Passed	
Port Maitland Consolidated School	PM11 - CF - P - 001	Classroom Faucet	0.0028	Passed	0.0018	Passed	
Port Maitland Consolidated School	PM12 - KF - P - 001	Kitchen Faucet	0.0074	Passed	0.0069	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Port Maitland Consolidated School	PM12.1 - KF - P - 001	Kitchen Faucet	0.0027	Passed	0.0033	Passed	
Port Maitland Consolidated School	PM13 - WF - P - 001	Water Fountain	0.0029	Passed	-	Passed	
Port Maitland Consolidated School	PM14 - CF - P - 001	Classroom Faucet	0.0035	Passed	0.0039	Passed	
Port Maitland Consolidated School	PM15 - CF - P - 001	Classroom Faucet	0.0079	Passed	0.0040	Passed	
Port Maitland Consolidated School	PM16 - CF - P - 002	Classroom Faucet	0.0310	Passed	0.0041	Passed	
Port Maitland Consolidated School	PM17 - BF - P - 002	Bathroom Faucet	0.0032	Passed	0.0007	Passed	
Port Maitland Consolidated School	PM18 - BF - P - 002	Bathroom Faucet	0.0020	Passed	-	Passed	
Port Maitland Consolidated School	PM19 - WF - P - 002	Water Fountain	0.0017	Passed	-	Passed	

Port Maitland Consolidated School	PM2 - BF - P - 001	Bathroom Faucet	0.0023	Passed	0.0007	Passed	
Port Maitland Consolidated School	PM20 - BF - P - 002	Bathroom Faucet	0.0021	Passed	0.0005	Passed	
Port Maitland Consolidated School	PM21 - BF - P - 002	Bathroom Faucet	0.0029	Passed	-	Passed	
Port Maitland Consolidated School	PM22 - BF - P - 002	Bathroom Faucet	0.0068	Passed	0.0016	Passed	
Port Maitland Consolidated School	PM23 - SF - P - 002	Staff Faucet	0.0039	Passed	0.0006	Passed	
Port Maitland Consolidated School	PM3 - BF - P - 001	Bathroom Faucet	0.0016	Passed	0.0013	Passed	
Port Maitland Consolidated School	PM4 - BF - P - 001	Bathroom Faucet	0.0032	Passed	0.0009	Passed	
Port Maitland Consolidated School	PM5 - BF - P - 001	Bathroom Faucet	0.0031	Passed	0.0014	Passed	
Port Maitland Consolidated School	PM6 - BF - P - 001	Bathroom Faucet	0.0023	Passed	0.0018	Passed	
Port Maitland Consolidated School	PM7 - BF - P - 001	Bathroom Faucet	0.0019	Passed	0.0009	Passed	
Port Maitland Consolidated School	PM8 - BF - P - 001	Bathroom Faucet	0.0072	Passed	0.0015	Passed	
Port Maitland Consolidated School	PM9 - WF - P - 001	Water Fountain	0.0032	Passed	-	Passed	
Shelburne Regional High School	SH10-BF-P-001	Bathroom Faucet	0.3603	Passed	0.0051	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH11-BF-P-001	Bathroom Faucet	1.0335	Passed	0.0054	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH12-BF-P-001	Bathroom Faucet	1.0605	Passed	0.0036	Passed	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH13-BF-P-001	Bathroom Faucet	0.8985	Passed	0.0041	Passed	
Shelburne Regional High School	SH14-BF-P-001	Bathroom Faucet	0.8379	Passed	0.0078	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH15-BF-P-001	Bathroom Faucet	0.9667	Passed	0.0067	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH16-WF-P-001	Water Fountain	0.0538	Passed	0.0016	Passed	
Shelburne Regional High School	SH17-BF-P-001	Bathroom Faucet	0.8547	Passed	0.0117	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH18-SF-P-001	Staff Faucet	0.3720	Passed	0.0360	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Shelburne Regional High School	SH19-BF-P-001	Bathroom Faucet	0.5357	Passed	0.0066	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH1-CF-P-001	Classroom Faucet	0.7433	Passed	0.0060	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH20-SF-P-001	Staff Faucet	0.2634	Passed	0.0030	Passed	
Shelburne Regional High School	SH21-BF-P-001	Bathroom Faucet	0.5429	Passed	0.0044	Passed	
Shelburne Regional High School	SH22-BF-P-001	Bathroom Faucet	0.6731	Passed	0.0027	Passed	
Shelburne Regional High School	SH23-BF-P-001	Bathroom Faucet	0.3055	Passed	0.0047	Passed	
Shelburne Regional High School	SH24-BF-P-001	Bathroom Faucet	1.5825	Passed	0.0034	Passed	
Shelburne Regional High School	SH25-BF-P-001	Bathroom Faucet	1.4150	Passed	0.0043	Passed	
Shelburne Regional High School	SH26-BF-P-001	Bathroom Faucet	0.6604	Passed	0.0056	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH27.1-CS-P-001	Custodial Sink	0.3553	Passed	0.0062	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH27-BF-P-001	Bathroom Faucet	0.7927	Passed	0.0055	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH29-WF-P-001	Water Fountain	2.0645	Exceeds Limit	0.0005	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Shelburne Regional High School	SH2-CS-P-001	Custodial Sink	0.2971	Passed	0.0011	Passed	
Shelburne Regional High School	SH30-BF-P-001	Bathroom Faucet	0.7191	Passed	0.0064	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH31-BF-P-001	Bathroom Faucet	0.7490	Passed	0.0068	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH32-BF-P-001	Bathroom Faucet	0.9816	Passed	0.0085	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH33-BF-P-001	Bathroom Faucet	1.5840	Passed	0.0098	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH34-BF-P-001	Bathroom Faucet	1.1615	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH35-BF-P-001	Bathroom Faucet	0.9356	Passed	0.0073	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH36-BF-P-001	Bathroom Faucet	0.4321	Passed	0.0091	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH37-BF-P-001	Bathroom Faucet	0.4605	Passed	0.0014	Passed	
Shelburne Regional High School	SH38-BF-P-001	Bathroom Faucet	1.6060	Passed	0.0050	Passed	
Shelburne Regional High School	SH39-BF-P-001	Bathroom Faucet	2.1670	Exceeds Limit	0.0069	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH3-KF-P-001	Kitchen Faucet	0.2438	Passed	0.0114	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Shelburne Regional High School	SH40-CS-P-001	Custodial Sink	0.3210	Passed	0.0030	Passed	
Shelburne Regional High School	SH41-CF-P-001	Classroom Faucet	0.3506	Passed	0.0040	Passed	
Shelburne Regional High School	SH42-CF-P-001	Classroom Faucet	0.1138	Passed	0.0303	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH43-WF-P-002	Water Fountain	0.9154	Passed	0.0004	Passed	
Shelburne Regional High School	SH44-BF-P-002	Bathroom Faucet	1.0965	Passed	0.0047	Passed	
Shelburne Regional High School	SH45-BF-P-002	Bathroom Faucet	1.1200	Passed	0.0059	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH46-BF-P-002	Bathroom Faucet	0.8420	Passed	0.0049	Passed	

Shelburne Regional High School	SH47-CF-P-002	Classroom Faucet	0.1351	Passed	0.0059	Exceeds Limit	
Shelburne Regional High School	SH48-CF-P-002	Classroom Faucet	0.2379	Passed	0.0062	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH4-KF-P-001	Kitchen Faucet	0.2661	Passed	0.0081	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Shelburne Regional High School	SH50-CS-P-002	Custodial Sink	0.3459	Passed	0.0011	Passed	
Shelburne Regional High School	SH51-BF-P-002	Bathroom Faucet	0.4590	Passed	0.0019	Passed	
Shelburne Regional High School	SH52-SF-P-002	Staff Faucet	0.2205	Passed	0.0032	Passed	
Shelburne Regional High School	SH53-CF-P-002	Classroom Faucet	0.3085	Passed	0.0026	Passed	
Shelburne Regional High School	SH54-CF-P-002	Classroom Faucet	0.2630	Passed	0.0026	Passed	
Shelburne Regional High School	SH55-CF-P-002	Classroom Faucet	0.2963	Passed	0.0036	Passed	
Shelburne Regional High School	SH56-CF-P-002	Classroom Faucet	0.3293	Passed	0.0019	Passed	
Shelburne Regional High School	SH57-CF-P-002	Classroom Faucet	0.3758	Passed	0.0039	Passed	
Shelburne Regional High School	SH58-CF-P-002	Classroom Faucet	0.5910	Passed	0.0035	Passed	
Shelburne Regional High School	SH59-CF-P-002	Classroom Faucet	0.3509	Passed	0.0038	Passed	
Shelburne Regional High School	SH5-KF-P-001	Kitchen Faucet	0.1577	Passed	0.0390	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Shelburne Regional High School	SH60-CF-P-002	Classroom Faucet	0.3658	Passed	0.0042	Passed	
Shelburne Regional High School	SH61-CF-P-002	Classroom Faucet	0.1781	Passed	0.0128	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH62-CF-P-002	Classroom Faucet	0.2377	Passed	0.0149	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH63-CF-P-002	Classroom Faucet	0.3330	Passed	0.0090	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH64-CF-P-002	Classroom Faucet	0.1923	Passed	0.0081	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH65-CF-P-002	Classroom Faucet	0.2202	Passed	0.0063	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH66-CF-P-002	Classroom Faucet	0.2634	Passed	0.0072	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH67-BF-P-002	Bathroom Faucet	0.1866	Passed	0.0024	Passed	
Shelburne Regional High School	SH68-BF-P-002	Bathroom Faucet	1.1800	Passed	0.0054	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH69-BF-P-002	Bathroom Faucet	1.0955	Passed	0.0074	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH6-KF-P-001	Kitchen Faucet	0.6705	Passed	0.0038	Passed	
Shelburne Regional High School	SH70-CS-P-002	Custodial Sink	0.2761	Passed	0.0021	Passed	
Shelburne Regional High School	SH71-BF-P-002	Bathroom Faucet	0.7493	Passed	0.0067	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH72-BF-P-002	Bathroom Faucet	0.6879	Passed	0.0074	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH73-BF-P-002	Bathroom Faucet	0.8304	Passed	0.0166	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH74.1-CF-P-002	Classroom Faucet	0.4181	Passed	0.2064	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH74.2-CF-P-002	Classroom Faucet	0.2348	Passed	0.0268	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH74.3-CF-P-002	Classroom Faucet	0.2154	Passed	0.0108	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH74-CF-P-002	Classroom Faucet	0.1732	Passed	0.0166	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH75-CF-P-002	Classroom Faucet	0.2284	Passed	0.0137	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH76-CF-P-002	Classroom Faucet	0.2038	Passed	0.0053	Exceeds Limit	
Shelburne Regional High School	SH77-CF-P-002	Classroom Faucet	0.2711	Passed	0.0065	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH78.1-CF-P-002	Classroom Faucet	0.1666	Passed	0.0245	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH78-CF-P-002	Classroom Faucet	1.9918	Passed	0.1302	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH79-CF-P-002	Classroom Faucet	0.2737	Passed	0.0084	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH7-KF-P-001	Kitchen Faucet	0.3418	Passed	0.0170	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Shelburne Regional High School	SH80-CF-P-002	Classroom Faucet	0.1187	Passed	0.0300	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH81-CF-P-002	Classroom Faucet	0.6204	Passed	0.0131	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH82-CF-P-002	Classroom Faucet	0.2342	Passed	0.0722	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH83-CF-P-002	Classroom Faucet	0.7100	Passed	0.0370	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH86-WF-P-002	Water Fountain	0.0126	Passed	0.0018	Passed	
Shelburne Regional High School	SH87-BF-P-002	Bathroom Faucet	0.9259	Passed	0.0072	Exceeds Limit	Signage to be added to instruct handwashing only
Shelburne Regional High School	SH88-CF-P-002	Classroom Faucet	0.4512	Passed	0.0034	Passed	
Shelburne Regional High School	SH8-KF-P-001	Kitchen Faucet	0.2521	Passed	0.0035	Passed	
St. Mary's Bay Academy	SM10-CF-P-001	Classroom Faucet	0.3205	Passed	0.0051	Exceeds Limit	
St. Mary's Bay Academy	SM11.1-CS-P-001	Custodial Sink	0.4753	Passed	0.0109	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM11-BF-P-001	Bathroom Faucet	0.3358	Passed	0.0068	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM12-BF-P-001	Bathroom Faucet	0.6570	Passed	0.0183	Exceeds Limit	Signage to be added to instruct handwashing only

St. Mary's Bay Academy	SM13-BF-P-001	Bathroom Faucet	0.5331	Passed	0.0093	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM14-BF-P-001	Bathroom Faucet	0.2754	Passed	0.0007	Passed	
St. Mary's Bay Academy	SM15-BF-P-001	Bathroom Faucet	0.2683	Passed	0.0007	Passed	
St. Mary's Bay Academy	SM16-BF-P-001	Bathroom Faucet	0.1735	Passed	0.0013	Passed	
St. Mary's Bay Academy	SM17-KF-P-001	Kitchen Faucet	0.3499	Passed	0.0007	Passed	
St. Mary's Bay Academy	SM18-KF-P-001	Kitchen Faucet	0.3750	Passed	0.0014	Passed	
St. Mary's Bay Academy	SM19-KF-P-001	Kitchen Faucet	0.3663	Passed	0.0014	Passed	
St. Mary's Bay Academy	SM1-BF-P-001	Bathroom Faucet	0.3228	Passed	0.0097	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM20-KF-P-001	Kitchen Faucet	0.2342	Passed	0.0016	Passed	
St. Mary's Bay Academy	SM21-CF-P-001	Classroom Faucet	0.3508	Passed	0.0050	Passed	
St. Mary's Bay Academy	SM22-BF-P-001	Bathroom Faucet	0.3222	Passed	0.0006	Passed	
St. Mary's Bay Academy	SM23-CF-P-001	Classroom Faucet	0.3143	Passed	0.0006	Passed	
St. Mary's Bay Academy	SM24-WF-P-001	Water Fountain	0.3224	Passed	0.0010	Passed	
St. Mary's Bay Academy	SM25-BF-P-001	Bathroom Faucet	0.2225	Passed	0.0007	Passed	
St. Mary's Bay Academy	SM26.1-CS-P-001	Custodial Sink	0.2633	Passed	0.0354	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM26-BF-P-001	Bathroom Faucet	0.2122	Passed	0.0010	Passed	
St. Mary's Bay Academy	SM27-BF-P-001	Bathroom Faucet	0.5036	Passed	0.0046	Passed	
St. Mary's Bay Academy	SM28-BF-P-001	Bathroom Faucet	0.2744	Passed	0.0012	Passed	
St. Mary's Bay Academy	SM29-BF-P-001	Bathroom Faucet	0.3623	Passed	0.0045	Passed	
St. Mary's Bay Academy	SM2-BF-P-001	Bathroom Faucet	0.3003	Passed	0.0006	Passed	
St. Mary's Bay Academy	SM30-BF-P-001	Bathroom Faucet	0.3597	Passed	0.0013	Passed	
St. Mary's Bay Academy	SM31-BF-P-001	Bathroom Faucet	0.3156	Passed	0.0015	Passed	
St. Mary's Bay Academy	SM32-BF-P-001	Bathroom Faucet	0.3639	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM33-BF-P-001	Bathroom Faucet	0.2846	Passed	0.0011	Passed	
St. Mary's Bay Academy	SM34-BF-P-001	Bathroom Faucet	0.3493	Passed	0.0062	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM35-CF-P-001	Classroom Faucet	0.3569	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM36-BF-P-001	Bathroom Faucet	0.3515	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM37-CF-P-001	Classroom Faucet	0.0073	Passed	0.0010	Passed	
St. Mary's Bay Academy	SM38-CF-P-001	Classroom Faucet	0.2606	Passed	0.0044	Passed	
St. Mary's Bay Academy	SM39-CF-P-001	Classroom Faucet	0.2518	Passed	0.0020	Passed	
St. Mary's Bay Academy	SM3-BF-P-001	Bathroom Faucet	0.1589	Passed	0.0017	Passed	
St. Mary's Bay Academy	SM40-CF-P-001	Classroom Faucet	0.1794	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM41-CF-P-001	Classroom Faucet	0.1890	Passed	0.0024	Passed	
St. Mary's Bay Academy	SM42-CF-P-001	Classroom Faucet	0.1828	Passed	0.0023	Passed	
St. Mary's Bay Academy	SM43.1-CF-P-001	Classroom Faucet	0.3980	Passed	0.0113	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM43-BF-P-001	Bathroom Faucet	0.4208	Passed	0.0031	Passed	
St. Mary's Bay Academy	SM44-WF-P-001	Water Fountain	0.2773	Passed	0.0033	Passed	
St. Mary's Bay Academy	SM45-BF-P-001	Bathroom Faucet	0.2631	Passed	0.0016	Passed	
St. Mary's Bay Academy	SM46.1-CF-P-001	Classroom Faucet	0.2990	Passed	0.0023	Passed	
St. Mary's Bay Academy	SM46-BF-P-001	Bathroom Faucet	0.2871	Passed	0.0015	Passed	
St. Mary's Bay Academy	SM47-SF-P-001	Staff Faucet	1.5570	Passed	0.0092	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
St. Mary's Bay Academy	SM48-WF-P-001	Water Fountain	0.6165	Passed	0.0048	Passed	
St. Mary's Bay Academy	SM49-BF-P-001	Bathroom Faucet	0.3029	Passed	0.0158	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM4-BF-P-001	Bathroom Faucet	0.2919	Passed	0.0015	Passed	
St. Mary's Bay Academy	SM50-BF-P-001	Bathroom Faucet	0.0991	Passed	0.0028	Passed	
St. Mary's Bay Academy	SM51-BF-P-001	Bathroom Faucet	0.2393	Passed	0.0011	Passed	
St. Mary's Bay Academy	SM52-BF-P-001	Bathroom Faucet	0.2561	Passed	0.0022	Passed	
St. Mary's Bay Academy	SM53-BF-P-001	Bathroom Faucet	0.2492	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM54-BF-P-001	Bathroom Faucet	0.1973	Passed	0.0031	Passed	
St. Mary's Bay Academy	SM55-BF-P-001	Bathroom Faucet	0.1921	Passed	0.0046	Passed	
St. Mary's Bay Academy	SM56.1-CF-P-001	Classroom Faucet	0.3366	Passed	0.0011	Passed	
St. Mary's Bay Academy	SM56-BF-P-001	Bathroom Faucet	0.1601	Passed	0.0010	Passed	

St. Mary's Bay Academy	SM57-BF-P-001	Bathroom Faucet	0.2148	Passed	0.0014	Passed	
St. Mary's Bay Academy	SM58-CF-P-001	Classroom Faucet	0.3165	Passed	0.0010	Passed	
St. Mary's Bay Academy	SM59.1-CF-P-001	Classroom Faucet	0.2940	Passed	0.0024	Passed	
St. Mary's Bay Academy	SM59-CF-P-001	Classroom Faucet	0.3367	Passed	0.0031	Passed	
St. Mary's Bay Academy	SM5-BF-P-001	Bathroom Faucet	0.3122	Passed	0.0020	Passed	
St. Mary's Bay Academy	SM60-CF-P-001	Classroom Faucet	0.3251	Passed	0.0015	Passed	
St. Mary's Bay Academy	SM61-CF-P-001	Classroom Faucet	0.2526	Passed	0.0007	Passed	
St. Mary's Bay Academy	SM62-CF-P-001	Classroom Faucet	0.2767	Passed	0.0022	Passed	
St. Mary's Bay Academy	SM63-CF-P-001	Classroom Faucet	0.2822	Passed	0.0017	Passed	
St. Mary's Bay Academy	SM64-CF-P-001	Classroom Faucet	0.2044	Passed	0.0141	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM65.1-BF-P-001	Bathroom Faucet	0.3220	Passed	0.0010	Passed	
St. Mary's Bay Academy	SM65-WF-P-001	Water Fountain	0.2701	Passed	0.0020	Passed	
St. Mary's Bay Academy	SM66-BF-P-001	Bathroom Faucet	0.3170	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM67-BF-P-001	Bathroom Faucet	0.3472	Passed	0.0019	Passed	
St. Mary's Bay Academy	SM68-BF-P-001	Bathroom Faucet	0.3592	Passed	0.0022	Passed	
St. Mary's Bay Academy	SM69-BS-P-001		0.0535	Passed	-	Passed	
St. Mary's Bay Academy	SM6-BF-P-001	Bathroom Faucet	0.2993	Passed	0.0011	Passed	
St. Mary's Bay Academy	SM70-BF-P-001	Bathroom Faucet	0.2981	Passed	0.0008	Passed	
St. Mary's Bay Academy	SM71-BF-P-001	Bathroom Faucet	0.3117	Passed	0.0007	Passed	
St. Mary's Bay Academy	SM72-BF-P-001	Bathroom Faucet	0.2759	Passed	0.0008	Passed	
St. Mary's Bay Academy	SM73-BF-P-001	Bathroom Faucet	0.1686	Passed	0.0016	Passed	
St. Mary's Bay Academy	SM74-BF-P-001	Bathroom Faucet	0.3072	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM75-CF-P-001	Classroom Faucet	0.2120	Passed	0.0066	Exceeds Limit	Signage to be added to instruct handwashing only
St. Mary's Bay Academy	SM7-BF-P-001	Bathroom Faucet	0.2883	Passed	0.0009	Passed	
St. Mary's Bay Academy	SM8-BF-P-001	Bathroom Faucet	0.3777	Passed	0.0022	Passed	
St. Mary's Bay Academy	SM9-WF-P-001	Water Fountain	0.0043	Passed	0.0012	Passed	
Weymouth Consolidated School	W1 - CS - P - 00B	Custodial Sink	0.0940	Passed	0.0310	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W10 - CF - P - 001	Classroom Faucet	0.1200	Passed	0.0049	Passed	
Weymouth Consolidated School	W11 - KF - P - 001	Kitchen Faucet	0.1200	Passed	0.0060	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Weymouth Consolidated School	W13 - KF - P - 001	Kitchen Faucet	0.1200	Passed	0.0017	Passed	
Weymouth Consolidated School	W14 - KF - P - 001	Kitchen Faucet	0.1000	Passed	0.0110	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Weymouth Consolidated School	W15 - BF - P - 001	Bathroom Faucet	0.0920	Passed	0.0039	Passed	
Weymouth Consolidated School	W18 - BF - P - 001	Bathroom Faucet	0.1700	Passed	0.0026	Passed	
Weymouth Consolidated School	W19 - BF - P - 001	Bathroom Faucet	0.1600	Passed	0.0049	Passed	
Weymouth Consolidated School	W2 - SF - P - 001	Staff Faucet	0.1000	Passed	0.0038	Passed	
Weymouth Consolidated School	W20 - BF - P - 001	Bathroom Faucet	0.1700	Passed	0.0021	Passed	
Weymouth Consolidated School	W21 - WF - P - 001	Water Fountain	0.1100	Passed	0.0013	Passed	
Weymouth Consolidated School	W22 - CS - P - 001	Custodial Sink	0.1000	Passed	0.0013	Passed	
Weymouth Consolidated School	W23 - BF - P - 001	Bathroom Faucet	0.1200	Passed	0.0066	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W24 - BF - P - 001	Bathroom Faucet	0.1400	Passed	0.0048	Passed	
Weymouth Consolidated School	W25 - BF - P - 001	Bathroom Faucet	0.1200	Passed	0.0025	Passed	
Weymouth Consolidated School	W26 - BF - P - 001	Bathroom Faucet	0.1100	Passed	0.0040	Passed	
Weymouth Consolidated School	W29 - BF - P - 001	Bathroom Faucet	0.1600	Passed	0.0043	Passed	
Weymouth Consolidated School	W3 - CF - P - 001	Classroom Faucet	0.1600	Passed	0.0069	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W30 - BF - P - 001	Bathroom Faucet	0.1600	Passed	0.0028	Passed	
Weymouth Consolidated School	W31 - BF - P - 001	Bathroom Faucet	0.1900	Passed	0.0051	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W33 - BF - P - 001	Bathroom Faucet	0.1600	Passed	0.0047	Passed	
Weymouth Consolidated School	W34 - CF - P - 001	Classroom Faucet	2.2000	Exceeds Limit	0.1300	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W36 - BF - P - 001	Bathroom Faucet	0.0950	Passed	0.0025	Passed	
Weymouth Consolidated School	W37 - BF - P - 001	Bathroom Faucet	0.0830	Passed	0.0023	Passed	
Weymouth Consolidated School	W38 - BF - P - 001	Bathroom Faucet	0.0620	Passed	0.0015	Passed	
Weymouth Consolidated School	W39 - CS - P - 001	Custodial Sink	0.1700	Passed	0.0056	Exceeds Limit	Signage to be added to instruct handwashing only

Weymouth Consolidated School	W4 - CF - P - 001	Classroom Faucet	0.2500	Passed	0.0052	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W40 - BF - P - 001	Bathroom Faucet	0.1300	Passed	0.0019	Passed	
Weymouth Consolidated School	W41 - BF - P - 001	Bathroom Faucet	0.1900	Passed	0.0023	Passed	
Weymouth Consolidated School	W42 - BF - P - 001	Bathroom Faucet	0.1100	Passed	0.0014	Passed	
Weymouth Consolidated School	W5 - CF - P - 001	Classroom Faucet	0.1800	Passed	0.0180	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W6 - CF - P - 001	Classroom Faucet	0.2000	Passed	0.0096	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W8 - CF - P - 001	Classroom Faucet	0.2500	Passed	0.0075	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	W9 - CF - P - 001	Classroom Faucet	0.2100	Passed	0.0075	Exceeds Limit	Signage to be added to instruct handwashing only
Weymouth Consolidated School	WF17 - WF - P - 001	Water Fountain	0.1200	Passed	-	Passed	
Weymouth Consolidated School	WF28 - WF - P - 001	Water Fountain	0.0720	Passed	-	Passed	
Weymouth Consolidated School	WF35 - WF - P - 001	Water Fountain	0.1100	Passed	0.0015	Passed	
Yarmouth Consolidated Memorial High School	YH100-CF-P-002	Classroom Faucet	2.9570	Exceeds Limit	0.0040	Passed	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH101-CF-P-002	Classroom Faucet	0.4010	Passed	0.0210	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH102-CF-P-002	Classroom Faucet	0.4340	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH103-CF-P-002	Classroom Faucet	0.5110	Passed	0.0050	Passed	
Yarmouth Consolidated Memorial High School	YH104-CS-P-002	Custodial Sink	0.2560	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH10-BF-P-001	Bathroom Faucet	0.4460	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH11-BF-P-001	Bathroom Faucet	0.3690	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH12-BF-P-001	Bathroom Faucet	0.3860	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH13-BF-P-001	Bathroom Faucet	0.4370	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH14-BF-P-001	Bathroom Faucet	0.7100	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH15-BF-P-001	Bathroom Faucet	0.3440	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH16-BF-P-001	Bathroom Faucet	0.3980	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH17-BF-P-001	Bathroom Faucet	0.4780	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH18-BF-P-001	Bathroom Faucet	0.3360	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH19-BF-P-001	Bathroom Faucet	0.3480	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH1-CS-P-001	Custodial Sink	0.3640	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH20-BF-P-001	Bathroom Faucet	0.3610	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH21-WF-P-001	Water Fountain	0.0070	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH22-BF-P-001	Bathroom Faucet	0.4420	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH23-BF-P-001	Bathroom Faucet	0.2990	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH24-BF-P-001	Bathroom Faucet	0.2870	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH25-BF-P-001	Bathroom Faucet	0.3720	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH26-KF-P-001	Kitchen Faucet	0.1380	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH27.1-KF-P-001	Kitchen Faucet	0.2820	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH27-KF-P-001	Kitchen Faucet	0.3010	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH28-KF-P-001	Kitchen Faucet	0.7540	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH29-CS-P-001	Custodial Sink	0.2870	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH2-CF-P-001	Classroom Faucet	0.2640	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH31-CF-P-001	Classroom Faucet	0.3220	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH32-BF-P-001	Bathroom Faucet	0.3560	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH33-WF-P-001	Water Fountain	0.0320	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH34-CS-P-001	Custodial Sink	0.5450	Passed	0.0040	Passed	
Yarmouth Consolidated Memorial High School	YH35-BF-P-001	Bathroom Faucet	0.4620	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH36-BF-P-001	Bathroom Faucet	0.4510	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH37-BF-P-001	Bathroom Faucet	0.4390	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH38-BF-P-001	Bathroom Faucet	0.3580	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH39-BF-P-001	Bathroom Faucet	0.4480	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH3-CF-P-001	Classroom Faucet	0.2950	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH40-BF-P-001	Bathroom Faucet	0.4090	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH41-BF-P-001	Bathroom Faucet	0.4050	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH42-BF-P-001	Bathroom Faucet	0.0490	Passed	0.0020	Passed	

Yarmouth Consolidated Memorial High School	YH43-BF-P-001	Bathroom Faucet	1.2090	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH44-CF-P-001	Classroom Faucet	0.3280	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH45-CF-P-002	Classroom Faucet	0.6190	Passed	0.0370	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH46-CF-P-002	Classroom Faucet	0.5320	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH47-CF-P-002	Classroom Faucet	0.6760	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH48-CF-P-002	Classroom Faucet	1.0660	Passed	0.0050	Passed	
Yarmouth Consolidated Memorial High School	YH49.1-CF-P-002	Classroom Faucet	1.0940	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH49.2-CF-P-002	Classroom Faucet	0.5750	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH49-CF-P-002	Classroom Faucet	1.0350	Passed	0.0040	Passed	
Yarmouth Consolidated Memorial High School	YH4-CF-P-001	Classroom Faucet	0.3250	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH50-CF-P-002	Classroom Faucet	0.3250	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH51-CF-P-002	Classroom Faucet	0.5640	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH52-CF-P-002	Classroom Faucet	0.9780	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH53-CF-P-002	Classroom Faucet	0.3240	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH54-CF-P-002	Classroom Faucet	0.5170	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH55-CF-P-002	Classroom Faucet	1.2430	Passed	0.0040	Passed	
Yarmouth Consolidated Memorial High School	YH56-CF-P-002	Classroom Faucet	0.2720	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH57-CF-P-002	Classroom Faucet	1.0000	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH58-CF-P-002	Classroom Faucet	0.7670	Passed	0.0070	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH59-CF-P-002	Classroom Faucet	0.6640	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH5-CF-P-001	Classroom Faucet	0.3130	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH61-CS-P-002	Custodial Sink	0.3070	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH62-CF-P-002	Classroom Faucet	0.6390	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH63-CF-P-002	Classroom Faucet	0.5640	Passed	0.0050	Passed	
Yarmouth Consolidated Memorial High School	YH64-CF-P-002	Classroom Faucet	0.6680	Passed	0.0040	Passed	
Yarmouth Consolidated Memorial High School	YH65-CF-P-002	Classroom Faucet	0.7360	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH66-CF-P-002	Classroom Faucet	0.2130	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH67-BF-P-002	Bathroom Faucet	0.5810	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH68-CS-P-002	Custodial Sink	0.5200	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH69-BF-P-002	Bathroom Faucet	0.3270	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH6-CF-P-001	Classroom Faucet	0.3530	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH70-BF-P-002	Bathroom Faucet	0.2610	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH71-SF-P-002	Staff Faucet	0.4530	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH72-CS-P-002	Custodial Sink	0.1090	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH73-WF-P-002	Water Fountain	0.0150	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH74-CS-P-002	Custodial Sink	0.5180	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH75-BF-P-002	Bathroom Faucet	0.3040	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH76-BF-P-002	Bathroom Faucet	0.3600	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH77-BF-P-002	Bathroom Faucet	0.3450	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH78-BF-P-002	Bathroom Faucet	0.3080	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH79-BF-P-002	Bathroom Faucet	0.4990	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH7-CF-P-001	Classroom Faucet	0.3400	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH80-BF-P-002	Bathroom Faucet	0.3530	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH81-BF-P-002	Bathroom Faucet	0.3200	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH82-CF-P-002	Classroom Faucet	0.1870	Passed	0.0040	Passed	
Yarmouth Consolidated Memorial High School	YH83-CF-P-002	Classroom Faucet	0.3420	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH84-CF-P-002	Classroom Faucet	1.1700	Passed	0.0050	Passed	
Yarmouth Consolidated Memorial High School	YH85-CF-P-002	Classroom Faucet	0.8610	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH86-CF-P-002	Classroom Faucet	0.6140	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH87-CF-P-002	Classroom Faucet	0.5100	Passed	0.0020	Passed	
Yarmouth Consolidated Memorial High School	YH88-CF-P-002	Classroom Faucet	0.7750	Passed	0.0030	Passed	
Yarmouth Consolidated Memorial High School	YH89-WF-P-002	Water Fountain	0.0110	Passed	0.0010	Passed	

Yarmouth Consolidated Memorial High School	YH8-WF-P-001	Water Fountain	0.0370	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH90-CS-P-002	Custodial Sink	0.5220	Passed	0.0130	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH91-BF-P-002	Bathroom Faucet	0.4800	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH92-BF-P-002	Bathroom Faucet	0.3490	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH93-BF-P-002	Bathroom Faucet	0.3710	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH94-BF-P-002	Bathroom Faucet	0.1610	Passed	-	Passed	
Yarmouth Consolidated Memorial High School	YH95-BF-P-002	Bathroom Faucet	0.3520	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH96-BF-P-002	Bathroom Faucet	0.4900	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH97-BF-P-002	Bathroom Faucet	0.3720	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH98-CF-P-002	Classroom Faucet	0.3780	Passed	0.0010	Passed	
Yarmouth Consolidated Memorial High School	YH99-CF-P-002	Classroom Faucet	2.2700	Exceeds Limit	0.0020	Passed	Signage to be added to instruct handwashing only
Yarmouth Consolidated Memorial High School	YH9-CS-P-001	Custodial Sink	0.6370	Passed	0.0100	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Elementary School	YE10-BF-P-001	Bathroom Faucet	0.1050	Passed	0.0010	Passed	
Yarmouth Elementary School	YE11-BF-P-001	Bathroom Faucet	0.1540	Passed	-	Passed	
Yarmouth Elementary School	YE12-BF-P-001	Bathroom Faucet	0.1050	Passed	-	Passed	
Yarmouth Elementary School	YE13-BF-P-001	Bathroom Faucet	0.3220	Passed	0.0010	Passed	
Yarmouth Elementary School	YE14-BF-P-001	Bathroom Faucet	0.4390	Passed	0.0010	Passed	
Yarmouth Elementary School	YE15-BF-P-001	Bathroom Faucet	0.3430	Passed	0.0010	Passed	
Yarmouth Elementary School	YE16-BF-P-001	Bathroom Faucet	0.3500	Passed	0.0010	Passed	
Yarmouth Elementary School	YE17-CF-P-001	Classroom Faucet	0.3170	Passed	0.0020	Passed	
Yarmouth Elementary School	YE18-CF-P-001	Classroom Faucet	0.3980	Passed	0.0010	Passed	
Yarmouth Elementary School	YE19-BF-P-001	Bathroom Faucet	0.0530	Passed	0.0010	Passed	
Yarmouth Elementary School	YE1-CF-P-001	Classroom Faucet	0.1680	Passed	0.0010	Passed	
Yarmouth Elementary School	YE20-BF-P-001	Bathroom Faucet	0.0600	Passed	0.0010	Passed	
Yarmouth Elementary School	YE21-BF-P-001	Bathroom Faucet	0.0600	Passed	0.0010	Passed	
Yarmouth Elementary School	YE22-CS-P-001	Custodial Sink	0.4400	Passed	0.0020	Passed	
Yarmouth Elementary School	YE23-WF-P-001	Water Fountain	0.4500	Passed	0.0010	Passed	
Yarmouth Elementary School	YE24-WF-P-001	Water Fountain	0.5490	Passed	0.0010	Passed	
Yarmouth Elementary School	YE25-CS-P-001	Custodial Sink	0.1110	Passed	0.0010	Passed	
Yarmouth Elementary School	YE27-CF-P-001	Classroom Faucet	0.2570	Passed	0.0010	Passed	
Yarmouth Elementary School	YE28-BF-P-001	Bathroom Faucet	0.4650	Passed	0.0010	Passed	
Yarmouth Elementary School	YE29-BF-P-001	Bathroom Faucet	0.4320	Passed	0.0010	Passed	
Yarmouth Elementary School	YE2-BF-P-001	Bathroom Faucet	0.1320	Passed	0.0010	Passed	
Yarmouth Elementary School	YE30-CF-P-001	Classroom Faucet	0.1860	Passed	0.0010	Passed	
Yarmouth Elementary School	YE31-BF-P-001	Bathroom Faucet	0.4970	Passed	0.0010	Passed	
Yarmouth Elementary School	YE32-CF-P-001	Classroom Faucet	0.2420	Passed	0.0010	Passed	
Yarmouth Elementary School	YE33-CF-P-001	Classroom Faucet	0.2420	Passed	0.0010	Passed	
Yarmouth Elementary School	YE34-BF-P-001	Bathroom Faucet	0.3300	Passed	0.0010	Passed	
Yarmouth Elementary School	YE35-BF-P-001	Bathroom Faucet	0.5300	Passed	0.0010	Passed	
Yarmouth Elementary School	YE36-CF-P-001	Classroom Faucet	0.2100	Passed	0.0010	Passed	
Yarmouth Elementary School	YE37-CF-P-001	Classroom Faucet	0.2530	Passed	0.0010	Passed	
Yarmouth Elementary School	YE38-CF-P-001	Classroom Faucet	0.1910	Passed	0.0010	Passed	
Yarmouth Elementary School	YE39-KF-P-001	Kitchen Faucet	0.0530	Passed	0.0010	Passed	
Yarmouth Elementary School	YE3-KF-P-001	Kitchen Faucet	0.1590	Passed	0.0010	Passed	
Yarmouth Elementary School	YE40-KF-P-001	Kitchen Faucet	0.3010	Passed	0.0020	Passed	
Yarmouth Elementary School	YE41-KF-P-001	Kitchen Faucet	0.4320	Passed	0.0040	Passed	
Yarmouth Elementary School	YE42-KF-P-001	Kitchen Faucet	0.7660	Passed	0.0160	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Yarmouth Elementary School	YE43-CF-P-002	Classroom Faucet	0.2060	Passed	0.0010	Passed	
Yarmouth Elementary School	YE44-CF-P-002	Classroom Faucet	0.1760	Passed	0.0010	Passed	
Yarmouth Elementary School	YE45-CF-P-002	Classroom Faucet	0.1920	Passed	0.0010	Passed	
Yarmouth Elementary School	YE46-WF-P-002	Water Fountain	0.6280	Passed	0.0010	Passed	
Yarmouth Elementary School	YE47-CF-P-002	Classroom Faucet	0.2070	Passed	0.0010	Passed	

Yarmouth Elementary School	YE48-BF-P-002	Bathroom Faucet	0.4750	Passed	0.0010	Passed	
Yarmouth Elementary School	YE49-CF-P-002	Classroom Faucet	0.2030	Passed	0.0010	Passed	
Yarmouth Elementary School	YE50-BF-P-002	Bathroom Faucet	0.3320	Passed	0.0010	Passed	
Yarmouth Elementary School	YE51-SF-P-002	Staff Faucet	0.2980	Passed	0.0010	Passed	
Yarmouth Elementary School	YE52-CS-P-002	Custodial Sink	0.5590	Passed	0.0040	Passed	
Yarmouth Elementary School	YE53-CF-P-002	Classroom Faucet	0.2320	Passed	0.0010	Passed	
Yarmouth Elementary School	YE54-BF-P-002	Bathroom Faucet	0.0870	Passed	0.0020	Passed	
Yarmouth Elementary School	YE55-BF-P-002	Bathroom Faucet	0.0930	Passed	0.0010	Passed	
Yarmouth Elementary School	YE56-BF-P-002	Bathroom Faucet	0.0850	Passed	0.0010	Passed	
Yarmouth Elementary School	YE57-CF-P-002	Classroom Faucet	0.2740	Passed	0.0010	Passed	
Yarmouth Elementary School	YE58-CF-P-002	Classroom Faucet	0.2860	Passed	0.0010	Passed	
Yarmouth Elementary School	YE59-CS-P-001	Custodial Sink	0.1550	Passed	0.0020	Passed	
Yarmouth Elementary School	YE5-CF-P-001	Classroom Faucet	0.2300	Passed	0.0010	Passed	
Yarmouth Elementary School	YE60-CS-P-002	Custodial Sink	0.1890	Passed	-	Passed	
Yarmouth Elementary School	YE61-CS-P-002	Custodial Sink	0.2710	Passed	0.0010	Passed	
Yarmouth Elementary School	YE6-BF-P-001	Bathroom Faucet	0.5330	Passed	0.0010	Passed	
Yarmouth Elementary School	YE7-BF-P-001	Bathroom Faucet	0.4290	Passed	0.0010	Passed	
Yarmouth Elementary School	YE8-WF-P-001	Water Fountain	0.1320	Passed	-	Passed	
Yarmouth Elementary School	YE9.1-CS-P-001	Custodial Sink	0.1160	Passed	0.0170	Exceeds Limit	Signage to be added to instruct handwashing only
Yarmouth Elementary School	YE9-WF-P-001	Water Fountain	0.1340	Passed	0.0010	Passed	